

ELECTRICAL INSTALLATION CONDITION REPORT

DLC58161 - Duplicate



A. Details of the Client/Person Ordering the Report		B. Reason for Producing this Report																					
Client: <input type="text" value="P.C.C.All Saints"/> Address: <input type="text" value="All Saints Church"/> <input type="text" value="Church Street"/> <input type="text" value="Martock"/> <input type="text" value="Somerset"/> <input type="text" value="TA12 6JL"/>	Purpose of this report: <input style="width: 100%;" type="text" value="ROUTINE ELECTRICAL INSPECTION AFTER RECENT
REMEDIAL WORKS CARRIED OUT."/> Date(s) on which Inspection: and testing was carried out <input type="text" value="16/08/2018"/>																						
C. Details of the Installation which is the Subject of this Report																							
Installation: <input type="text" value="AllSaints Church"/> Occupier: <input type="text" value="Mr Allwood"/> Address: <input type="text" value="All Saints Church"/> <input type="text" value="Church Street"/> <input type="text" value="Martock"/> <input type="text" value="TA12 6JL"/>	<table style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 33%;">Description of premises:</td> <td style="width: 16.5%; text-align: center;"><input type="text" value="N/A"/></td> <td style="width: 16.5%; text-align: center;"><input type="text" value="N/A"/></td> <td style="width: 33%; text-align: center;"><input type="text" value="N/A"/></td> </tr> <tr> <td>Other:</td> <td colspan="3"><input style="width: 100%;" type="text" value="CHURCH"/></td> </tr> <tr> <td>Estimated age of wiring system:</td> <td colspan="2"></td> <td style="text-align: right;"><input type="text" value="50"/> yrs</td> </tr> <tr> <td>Evidence of alterations or additions:</td> <td style="text-align: center;"><input checked="" type="checkbox"/></td> <td style="text-align: center;">If yes estimated Age</td> <td style="text-align: right;"><input type="text" value="0"/> yrs</td> </tr> <tr> <td>Record of Installation available: <input checked="" type="checkbox"/></td> <td>Records held By: <input type="text" value="JLS Heating and electrical Lt"/></td> <td>Date of previous inspection:</td> <td style="text-align: right;"><input type="text" value="19/07/2016"/></td> </tr> </table>			Description of premises:	<input type="text" value="N/A"/>	<input type="text" value="N/A"/>	<input type="text" value="N/A"/>	Other:	<input style="width: 100%;" type="text" value="CHURCH"/>			Estimated age of wiring system:			<input type="text" value="50"/> yrs	Evidence of alterations or additions:	<input checked="" type="checkbox"/>	If yes estimated Age	<input type="text" value="0"/> yrs	Record of Installation available: <input checked="" type="checkbox"/>	Records held By: <input type="text" value="JLS Heating and electrical Lt"/>	Date of previous inspection:	<input type="text" value="19/07/2016"/>
Description of premises:	<input type="text" value="N/A"/>	<input type="text" value="N/A"/>	<input type="text" value="N/A"/>																				
Other:	<input style="width: 100%;" type="text" value="CHURCH"/>																						
Estimated age of wiring system:			<input type="text" value="50"/> yrs																				
Evidence of alterations or additions:	<input checked="" type="checkbox"/>	If yes estimated Age	<input type="text" value="0"/> yrs																				
Record of Installation available: <input checked="" type="checkbox"/>	Records held By: <input type="text" value="JLS Heating and electrical Lt"/>	Date of previous inspection:	<input type="text" value="19/07/2016"/>																				
D. Extent and Limitations Inspection and Testing																							
Extent of Electrical Installation covered by this report: <input style="width: 100%;" type="text" value="Full visual inspection."/> --See Additional Page--		Agreed limitations including the reasons (See regulation 634.2) <input style="width: 100%;" type="text" value="All fixed and portable equipment were disconnected before
--See Additional Page--"/>																					
Operational Limitations including the reasons (See page No <input type="text" value="N/A"/>) <input style="width: 100%;" type="text" value="None"/>		Agreed with name <input style="width: 100%;" type="text" value="Mr Allwood"/>																					
This inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS7671:2008 (IET Wiring Regulations) as amended to <input type="text" value="July 2015"/> It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces, and generally within the fabric of the building or underground, have NOT been inspected unless specifically agreed between the client and inspector prior to the inspection. An inspection should be made within an accessible roof space housing other electrical equipment.																							
E. Summary of the Condition of the Installation		General condition of the installations (In terms of electrical safety)																					
<input style="width: 100%;" type="text" value="THE GENERAL CONDITION OF THE INSTALLATION IS SATISFACTORY."/> --See Additional Page--																							
Overall assessment of the installation		<input style="width: 100%;" type="text" value="Satisfactory"/> *An unsatisfactory assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified.																					
F. Recommendations																							
Where the overall assessment of the suitability of the installation for continued use above is stated as <input type="text" value="SATISFACTORY"/> , I recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'further investigation required' (code F1). Observation classified as 'Improvement recommended' (code C3) should be given due consideration. Subject to the necessary remedial action being taken I recommend that the installation is further inspected and tested by <input type="text" value="16/08/2023"/>																							
G. Declaration																							
I , being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by My signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.																							
Trading Title and address <input style="width: 100%;" type="text" value="D L CREASE LTD,
CONTRACTING HOUSE,
1 CROMWELL ROAD,
Yeovil,
, BA21 5AN"/>	NICEIC Enrolment Number <input type="text" value="4319"/> Branch No. (If Applicable) <input type="text" value="N/A"/>																						
Inspected and tested by: Name <input type="text" value="T.GILLMAN"/> Position <input type="text" value="Qualifying supervisor"/> Signature <input style="width: 100px;" type="text"/> Date <input style="width: 100px;" type="text"/> Report authorised for issue by: Name <input type="text" value="T.GILLMAN"/> Position <input type="text" value="Qualifying supervisor"/> Signature <input style="width: 100px;" type="text"/> Date <input style="width: 100px;" type="text"/>																							
H. Schedule(s)																							
The attached schedule(s) are part of this document and this report is valid only when they are attached to it.																							
<input type="text" value="0"/> Schedule(s) of inspection and <input type="text" value="5"/> Schedule(s) of test results are attached																							

I. Supply Characteristics and Earthing Arrangements				Nature of Supply Parameters		Supply protective device	
Earthing Arrangements		Number and Type of Live Conductors					
TN-S	<input checked="" type="checkbox"/>	a.c.	<input checked="" type="checkbox"/>	d.c.	N/A	Nominal Voltage $U^{(1)}$	400 V
TN-C-S	N/A	1-Phase (2 wire)	N/A	1-Phase (3 wire)	N/A	Nominal Voltage $U_0^{(1)}$	230 V
TN-C	N/A	2-Phase (3 wire)	N/A	3 Wire	N/A	Nominal frequency $f^{(1)}$	50 Hz
TT	N/A	3-Phase (3 wire)	N/A	3-Phase (4 wire)	<input checked="" type="checkbox"/>	Prospective fault current $I_{pf}^{(2)}$	1.60 kA
IT	N/A	Other	N/A		N/A	External loop impedance $Z_e^{(2)}$	0.23 Ω
Confirmation of supply polarity				<input checked="" type="checkbox"/>		Number of supplies	1
						(Note: (1) by enquiry, (2) by enquiry or by measurement)	
						BS(EN)	1361 Fuse HBC
						Type	2
						Nominal current rating	100 A
						Short circuit capacity	33 kA

J. Particulars of Installation Referred to in the Report			
Means of earthing		Details of installation Earth Electrode (where applicable)	
Distributor's facility	<input checked="" type="checkbox"/>	Type (e.g. rod(s), tape etc.)	N/A
Installation earth electrode	N/A	Resistance to Earth	N/A Ω
		Location	N/A
		Method of measurement	N/A

Main Protective Conductors		Tick boxes and enter details as applicable	
Earthing Conductor	Material: Copper	csa: 16 mm ²	Connection and Continuity Verified <input checked="" type="checkbox"/>
Main protective bonding conductors	Material: Copper	csa: 10 mm ²	Connection and Continuity Verified <input checked="" type="checkbox"/>
Bonding of Incoming Service			Maximum Demand (Load)
Water installation pipes	<input checked="" type="checkbox"/>	Gas installation pipes	<input checked="" type="checkbox"/>
Oil installation pipes	N/A	Structural Steel	N/A
		Lightning protection	<input checked="" type="checkbox"/>
Other incoming service(s)		Please State	
N/A		N/A	
			60 Amps
			Protective measure(s) against electric shock
			ADS

Main Switch / Switch-Fuse / Circuit-Breaker / RCD					
Location	Main distribution board		Current rating	100 A	
Type BS(EN)	61008 RCD	No of poles	4	Fuse/Device rating or setting	100 A
Supply Conductors material	Copper	Supply Conductors csa	25 mm ²	Voltage rating	400 V
				if RCD main switch	
				Rated residual operation current, $I_{\Delta n}$	300 mA
				Rated time delay	197 ms
				RCD Operating time at, $I_{\Delta n}$	197 ms

K. Observations		
Referring to the attached schedule(s) of Inspection and Test Results, and subject to the limitations specified at the Extent and Limitations of the Inspection and testing section.		
No remedial action is required.	<input checked="" type="checkbox"/>	The following observations are made
		N/A
Item No	Observations	Code
One of the following codes, as appropriate, has been allocated to each of the observations made above to indicate to the person(s) responsible for the installation the degree of urgency for remedial action.		
C1 - Danger present. Risk of injury. Immediate remedial action required	<input type="text" value="0"/>	
C2 - Potentially dangerous - urgent remedial action required	<input type="text" value="0"/>	
C3 - Improvement recommended	<input type="text" value="0"/>	
FI - Further investigation required without delay	<input type="text" value="0"/>	

CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY

Note: this form is suitable for many types of smaller installations not exclusively domestic.

Outcomes	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item No	Description										Outcome	Comments		
1.0	DISTRIBUTOR'S / SUPPLY INTAKE EQUIPMENT													
1.1	Condition of service cable										✓	No		
1.2	Condition of Service head										✓	No		
1.3	Condition of distributor's earthing arrangement										✓	No		
1.4	Condition of meter tails - Distributor/Consumer										✓	No		
1.5	Condition of metering equipment										✓	No		
1.6	Condition of Isolator (where present)										✓	No		
2.0	PRESENCE OF ADEQUATE ARRANGEMENTS FOR PARALLEL OR SWITCHED ALTERNATIVE SOURCES										✓	No		
3.0	EARTHING / BONDING ARRANGEMENTS (411.3; Chap 54)													
3.1	Presence and condition of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)										✓	No		
3.2	Presence and condition of earth electrode connection where applicable (542.1.2.3)										N/A	No		
3.3	Provision of earthing/bonding labels at all appropriate locations (514.13.1)										✓	No		
3.4	Confirmation of earthing conductor size (542.3; 543.1.1)										✓	No		
3.5	Accessibility and condition of earthing conductor at MET (543.3.2)										✓	No		
3.6	Confirmation of main protective bonding conductor sizes (544.1)										✓	No		
3.7	Condition and accessibility of main protective bonding conductor connections (543.3.2; 544.1.2)										✓	No		
3.8	Accessibility and condition of other protective bonding connections (543.3.2)										✓	No		
4.0	CONSUMER UNIT (S) / DISTRIBUTION BOARD(S)													
4.1	Adequacy of working space / accessibility to consumer unit / distribution board (132.12; 513.1)										✓	No		
4.2	Security of fixing (134.1.1)										✓	No		
4.3	Condition of enclosure(s) in terms of IP rating etc (416.2)										✓	No		
4.4	Condition of enclosure(s) in terms of fire rating etc (421.1.201; 526.5)										✓	No		
4.5	Enclosure not damaged/deteriorated so as to impair safety (Regulation 621.2 (iii))										✓	No		
4.6	Presence of linked main switch (as required by 537.1.4)										✓	No		
4.7	Operation of main switch (functional check) (612.13.2)										✓	No		
4.8	Manual operation of circuit-breakers and RCDs to prove disconnection (612.13.2)										✓	No		
4.9	Correct identification of circuit details and protective devices (514.8.1;514.9.1)										✓	No		
4.10	Presence of RCD quarterly test notice at or near consumer unit / distribution board (514.12.2)										✓	No		
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit / distribution board (514.14)										✓	No		
4.12	Presence of alternative supply warning notice at or near consumer unit / distribution board (514.15)										N/A	No		
4.13	Presence of other required labelling (please specify)(Section 514)										✓	No		
4.14	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating)(421.1.3)										✓	No		
4.15	Single-pole switching or protective devices in line conductor only (132.14.1; 530.3.2)										✓	No		
4.16	Protection against mechanical damage where cables enter consumer unit / distribution board (522.8.1; 522.8.11)										✓	No		
4.17	Protection against electromagnetic effects where cables enter consumer unit / distribution board / enclosures (521.5.1))										✓	No		
4.18	RCD(s) provided for fault protection – includes RCBOs(411.4.9; 411.5.2; 531.2)										✓	No		
4.19	RCD(s) provided for additional protection - includes RCBOs (411.3.3; 415.1)										✓	No		
4.20	Confirmation of indication that SPD is functional (534.2.8)										✓	No		
4.21	Confirmation that ALL conductor connections, including connections to busbars are correctly located in terminals and are tight and secure (526.1)										✓	No		
4.22	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)										N/A	No		
4.23	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)										N/A	No		
5.0	FINAL CIRCUITS													
5.1	Identification of conductors (514.3.1)										✓	No		
5.2	Cables correctly supported throughout their run (522.8.5)										✓	No		
5.3	Condition of insulation of live parts (416.1)										✓	No		

CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100A SUPPLY CONTINUED

Note: this form is suitable for many types of smaller installations not exclusively domestic.

Outcomes	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Further investigation	FI	Not verified	N/V	Limitation	LIM	Not applicable	N/A
Item No	Description										Outcome	Comments		
5.0	FINAL CIRCUITS (Continued)													
5.4.0	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)										✓	No		
5.4.1	To include the integrity of conduit and trunking systems (metallic and plastic)										✓	No		
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)										✓	No		
5.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)										✓	No		
5.7	Adequacy of protective devices; type and rated current for fault protection (411.3)										✓	No		
5.8	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)										✓	No		
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)										✓	No		
5.10	Concealed cables installed in prescribed zones (see section D. Extent and limitations) (522.6.202)										✓	No		
5.11	Cables concealed under floors, above ceilings or in walls / partitions, adequately protected against damage (see Section D. Extent and limitations) (522.6.204)										N/A	No		
5.12.0	Provision of additional protection by RCD not exceeding 30mA													
5.12.1	For all socket-outlets of rating 20 A or less, unless an exception is permitted (411.3.3)										✓	No		
5.12.2	For supply to mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)										✓	No		
5.12.3	For cables concealed in walls at a depth of less than 50mm (522.6.202; 522.6.203)										N/A	No		
5.12.4	For cables concealed in walls / partitions containing metal parts regardless of depth (522.6.203)										N/A	No		
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)										✓	No		
5.14	Band II Cables segregated / separated from Band I cables (528.1)										✓	No		
5.15	Cables segregated / separated from communications cabling (528.2)										✓	No		
5.16	Cables segregated / separated from non-electrical services (528.3)										✓	No		
5.17.0	Termination of cables at enclosures – indicate extent of sampling in Section D of the report (Section 526)													
5.17.1	Connections soundly made and under no undue strain (526.6)										✓	No		
5.17.2	No basic insulation of a conductor visible outside enclosure (526.8)										✓	No		
5.17.3	Connections of live conductors adequately enclosed (526.5)										✓	No		
5.17.4	Adequately connected at point of entry to enclosure (glands, bushes etc...) (522.8.5)										✓	No		
5.18	Condition of accessories including socket-outlets, switches and joint boxes (621.2 (iii))										✓	No		
5.19	Suitability of accessories for external influences (512.2)										✓	No		
5.20	Adequacy of working space / accessibility to equipment (132.12; 513.1)										✓	No		
5.21	Single-pole switching or protective devices in line conductors only (132.14.1; 530.3.2)										✓	No		
6.0	LOCATION(S) CONTAINING A BATH OR SHOWER													
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30mA (701.411.3.3)										N/A	No		
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)										N/A	No		
6.3	Shaver sockets comply with BS EN 61558-2-5 formally BS 3535 (701.512.3)										N/A	No		
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671: 2008 (701.415.2)										N/A	No		
6.5	Low Voltage (e.g. 230 volts) socket outlets at least 3m from Zone 1 (701.512.3)										N/A	No		
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)										N/A	No		
6.7	Suitability of accessories and control gear etc. for a particular zone (701.512.3)										N/A	No		
6.8	Suitability of current-using equipment for particular position within the location (701.55)										N/A	No		
7.0	OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS													
7.1	List all other special installations or locations present, if any. (Record separately the results of particular inspections applied).									Number of locations	0	No		

Inspected By	
Name: T.GILLMAN	Date: N/A
Signature: <input type="text"/>	

Board Details		TO BE COMPLETED IN EVERY CASE		ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION	
Location of Distribution Board	Vestery	Supply to distribution board is from	N/A	Associated RCD (if any)	
Distribution board designation	DB 1 Main	No of phases	N/A	BS(EN)	N/A
		Nominal Voltage	N/A V	RCD No of Poles	N/A
		Overcurrent protective device for the distribution circuit		RCD Rating	N/A mA
		Type BS(EN)	N/A		
		Rating	N/A A		

Circuit Details													
Circuit number and phase	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max permitted disconnection times	Overcurrent protective device				RCD	Max permitted Zs Ω
					Live mm ²	cpc mm ²		BS(EN)	Type No	Rating A	Short circuit capacity kA		
1/TP	Organ supply	H	C	1	1.5	9.1	0.4	60898 MCB	C	16	10	300	1.09
2/TP	Heating system	F	D	1	6	40	0.4	60898 MCB	C	32	10	300	0.54
3/TP	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
4/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
4/L2	Lights.North tower	O	C	3	1.5	1	0.4	60898 MCB	C	10	10	300	1.75
4/L3	Lights.Vestry	B	B	3	1.5	1	0.4	60898 MCB	C	10	10	300	1.75
5/L1	Lights.Organ	O	C	4	1.5	1	0.4	60898 MCB	C	10	10	300	1.75
5/L2	Sub Mains(DB 5 Tower cupboard.)	D	B	1	2.5	1.5	0.4	60898 MCB	C	20	10	300	0.87
5/L3	Sub Mains(DB 4 Kitchen+Toilet)	F	C	1	10	41	5	60898 MCB	C	50	10	300	0.35
6/L1	Sub Mains(DB 3 Lighting +Power)	F	C	1	16	46	5	60898 MCB	C	63	10	300	0.28
6/L2	Sub Mains(DB 2 Outside lights)	F	D	1	2.5	1.5	0.4	60898 MCB	C	16	10	300	1.09
6/L3	Socket.Amplifier	O	C	1	2.5	1.5	0.4	61009 RCD/RCBO	C	16	10	30	1.09
7/TP	Surge protector	D	B	1	10	10	5	60898 MCB	C	63	10	300	0.28
8/TP	Heating.Lady chapel	F	C	3	6	40	0.4	60898 MCB	C	20	10	300	0.87
9/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
9/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
9/L3	Alarm	A	C	1	2.5	1.5	0.4	60898 MCB	C	10	10	300	1.75
10/L1	Heater point 1	O	C	1	2.5	1.5	0.4	60898 MCB	C	16	10	300	1.09
10/L2	Heater point 2	O	C	1	2.5	1.5	0.4	60898 MCB	C	16	10	300	1.09
10/L3	Heater point 4	O	C	1	2.5	1.5	0.4	60898 MCB	C	16	10	300	1.09
11/L1	Heater point south door	O	C	1	2.5	1.5	0.4	60898 MCB	C	16	10	300	1.09
11/L2	Heater point 3	O	C	1	2.5	1.5	0.4	60898 MCB	B	16	10	300	2.18
11/L3	Sockets.Adacent	A	C	1	2.5	1.5	0.4	61009 RCD/RCBO	C	16	10	30	1.09
12/L1	Sockets.Middle	O	C	4	2.5	1.5	0.4	61009 RCD/RCBO	C	20	10	30	0.87

Wiring Code								
A	B	C	D	E	F	G	H	O
PVC/PVC cables	PVC cables in metallic conduit	PVC cables in non-metallic conduit	PVC cables in metallic trunking	PVC cables in non-metallic trunking	PVC/SWA cables	XLPE/SWA cables	Mineral insulated cables	Other

Board Tests

ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION				TEST INSTRUMENTS (SERIAL NUMBERS) USED						
Zs	N/A	Ω	Operating times of associated RCD (if any)	At I Δ _n	N/A	ms	Earth fault loop impedance	100710/4745	RCD	100710/4745
Ipf	N/A	kA		At 5I Δ _n	N/A	ms	Insulation resistance	100710/4745	Other	N/A
Correct supply polarity confirmed	<input checked="" type="checkbox"/>		Phase sequence confirmed (where appropriate)		<input checked="" type="checkbox"/>		Continuity	100710/4745	Other	N/A

Details of circuits and/or equipment vulnerable to damage

All fixed and portable equipment were disconnected before testing.

Circuit Tests

Circuit number and phase	Circuit Impedances Ω					Insulation resistance				polar i t y	Maximum measured earth fault loop impedance Ω	RCD operating times			Remarks see continuation sheet
	Ring final circuits only (measure end to end)			All circuits (At least one column to be completed)		Live/ Live	Live/ Neutral	Live/ Earth	Earth/ Neutral			At I Δ _n	At 5I Δ _n	Test button operation	
	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	(R ₁ + R ₂)	(R ₂)	MΩ	MΩ	MΩ	MΩ			ms	ms		
1/TP	N/A	N/A	N/A	0.08	N/A	20	20	20	20	✓	0.31	197	N/A	✓	NO
2/TP	N/A	N/A	N/A	0.04	N/A	20	20	20	20	✓	0.27	197	N/A	✓	NO
3/TP	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
4/L2	N/A	N/A	N/A	0.30	N/A	N/A	200	200	200	✓	0.53	197	N/A	✓	NO
4/L3	N/A	N/A	N/A	0.38	N/A	N/A	2	2	2	✓	0.61	197	N/A	✓	NO
5/L1	N/A	N/A	N/A	0.38	N/A	N/A	200	200	200	✓	0.61	197	N/A	✓	NO
5/L2	N/A	N/A	N/A	0.51	N/A	N/A	20	20	20	✓	0.74	197	N/A	✓	NO
5/L3	N/A	N/A	N/A	0.10	N/A	N/A	20	20	20	✓	0.33	197	N/A	✓	NO
6/L1	N/A	N/A	N/A	0.04	N/A	N/A	20	20	20	✓	0.28	197	N/A	✓	NO
6/L2	N/A	N/A	N/A	0.02	N/A	N/A	200	200	200	✓	0.25	197	N/A	✓	NO
6/L3	N/A	N/A	N/A	0.31	N/A	N/A	200	200	200	✓	0.54	18	8	✓	NO
7/TP	N/A	N/A	N/A	0.01	N/A	200	200	200	200	✓	0.24	197	N/A	✓	NO
8/TP	N/A	N/A	N/A	0.31	N/A	200	20	20	20	✓	0.54	197	N/A	✓	NO
9/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
9/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
9/L3	N/A	N/A	N/A	0.03	N/A	N/A	200	200	200	✓	0.26	197	N/A	✓	NO
10/L1	N/A	N/A	N/A	0.49	N/A	N/A	200	200	200	✓	0.72	197	N/A	✓	NO
10/L2	N/A	N/A	N/A	0.56	N/A	N/A	200	200	200	✓	0.79	197	N/A	✓	NO
10/L3	N/A	N/A	N/A	0.32	N/A	N/A	200	200	200	✓	0.55	197	N/A	✓	NO
11/L1	N/A	N/A	N/A	0.49	N/A	N/A	200	200	200	✓	0.72	197	N/A	✓	NO
11/L2	N/A	N/A	N/A	0.36	N/A	N/A	200	200	200	✓	0.59	197	N/A	✓	NO
11/L3	N/A	N/A	N/A	0.04	N/A	N/A	200	200	200	✓	0.27	18	8	✓	NO
12/L1	N/A	N/A	N/A	0.47	N/A	N/A	200	200	200	✓	0.70	18	8	✓	NO

Tested By

Signature	<input type="text"/>	Position	Qualifying supervisor
Name	T.GILLMAN	Date of testing	16/08/2018

Board Details

TO BE COMPLETED IN EVERY CASE		ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION		
Location of Distribution Board	<input type="text" value="Vestery"/>	Supply to distribution board is from	<input type="text" value="N/A"/>	
Distribution board designation	<input type="text" value="DB 1 Main"/>	No of phases	<input type="text" value="N/A"/>	Nominal Voltage <input type="text" value="N/A"/> V
		Overcurrent protective device for the distribution circuit		Associated RCD (if any)
		Type BS(EN)	<input type="text" value="N/A"/>	Rating <input type="text" value="N/A"/> A
				BS(EN) <input type="text" value="N/A"/>
				RCD No of Poles <input type="text" value="N/A"/>
				RCD Rating <input type="text" value="N/A"/> mA

Circuit Details

Circuit number and phase	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max permitted disconnection times	Overcurrent protective device				RCD Op. current I Δn	Max permitted Zs Ω
					Live mm ²	cpc mm ²		BS(EN)	Type No	Rating A	Short circuit capacity kA		
12/L2	Sockets.North	O	C	6	2.5	1.5	0.4	61009 RCD/RCBO	C	20	10	30	0.87
12/L3	Sockets.South	O	C	5	2.5	1.5	0.4	61009 RCD/RCBO	C	20	10	30	0.87

Wiring Code

A	B	C	D	E	F	G	H	O
PVC/PVC cables	PVC cables in metallic conduit	PVC cables in non-metallic conduit	PVC cables in metallic trunking	PVC cables in non-metallic trunking	PVC/SWA cables	XLPE/SWA cables	Mineral insulated cables	Other

Board Tests

ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION		TEST INSTRUMENTS (SERIAL NUMBERS) USED						
Zs	N/A Ω	Operating times of associated RCD (if any)	At I Δ_n	N/A ms	Earth fault loop impedance	100710/4745	RCD	100710/4745
lpf	N/A kA		At 5I Δ_n	N/A ms	Insulation resistance	100710/4745	Other	N/A
Correct supply polarity confirmed	<input checked="" type="checkbox"/>		Phase sequence confirmed (where appropriate)	<input checked="" type="checkbox"/>		Continuity	100710/4745	Other

Details of circuits and/or equipment vulnerable to damage

All fixed and portable equipment were disconnected before testing.

Circuit Tests

Circuit number and phase	Circuit Impedances Ω					Insulation resistance				polarity	Maximum measured earth fault loop impedance Ω	RCD operating times			Remarks see continuation sheet
	Ring final circuits only (measure end to end)			All circuits (At least one column to be completed)		Live/ Live	Live/ Neutral	Live/ Earth	Earth/ Neutral			At I Δ_n ms	At 5I Δ_n ms	Test button operation	
	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	(R ₁ + R ₂)	(R ₂)										
12/L2	N/A	N/A	N/A	0.54	N/A	N/A	200	200	200	✓	0.77	18	8	✓	NO
12/L3	N/A	N/A	N/A	0.64	N/A	N/A	200	200	200	✓	0.87	18	8	✓	NO

Tested By

Signature	<input type="text"/>	Position	<input type="text" value="Qualifying supervisor"/>
Name	<input type="text" value="T.GILLMAN"/>	Date of testing	<input type="text" value="16/08/2018"/>

Board Details		
TO BE COMPLETED IN EVERY CASE	ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION	
Location of Distribution Board Vestry	Supply to distribution board is from SubMains(DB 1 Main, 6/L2/L2)	Associated RCD (if any) BS(EN) N/A
Distribution board designation DB 2 Outside lights	No of phases 1 Nominal Voltage 400 V Overcurrent protective device for the distribution circuit Type BS(EN) 60898 MCB C Rating 16 A	RCD No of Poles N/A RCD Rating N/A mA

Circuit number and phase	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max permitted disconnection times	Overcurrent protective device				RCD	Max permitted Zs Ω	
					Live mm ²	cpc mm ²		BS(EN)	Type No	Rating A	Short circuit capacity kA	Op. current I Δ _n		
1/L2	Outside flood lights.	F	D	2	1.5	15	0.4	60898 MCB	C	10	6	30	1.75	

Wiring Code								
A	B	C	D	E	F	G	H	O
PVC/PVC cables	PVC cables in metallic conduit	PVC cables in non-metallic conduit	PVC cables in metallic trunking	PVC cables in non-metallic trunking	PVC/SWA cables	XLPE/SWA cables	Mineral insulated cables	Other

Board Tests

ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

TEST INSTRUMENTS (SERIAL NUMBERS) USED

Zs Ω Operating times of associated RCD (if any) At I Δ_n ms

lpf kA At 5I Δ_n ms

Correct supply polarity confirmed Phase sequence confirmed (where appropriate)

Earth fault loop impedance RCD

Insulation resistance Other

Continuity Other

Details of circuits and/or equipment vulnerable to damage

All fixed and portable equipment were disconnected before testing.

Circuit Tests

Circuit number and phase	Circuit Impedances Ω					Insulation resistance				polarity	Maximum measured earth fault loop impedance Ω	RCD operating times			Remarks see continuation sheet
	Ring final circuits only (measure end to end)			All circuits (At least one column to be completed)		Live/ Live	Live/ Neutral	Live/ Earth	Earth/ Neutral			At $I \Delta_n$ ms	At $5I \Delta_n$ ms	Test button operation	
	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	(R ₁ + R ₂)	(R ₂)										
1/L2	N/A	N/A	N/A	2.71	N/A	N/A	200	200	200	✓	2.96	19	8	✓	NO

Tested By

Signature

Name

Position

Date of testing

Board Details	
TO BE COMPLETED IN EVERY CASE	ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
Location of Distribution Board Adjacent to pulpit	Supply to distribution board is from SubMains(DB 1 Main, 6/L1/L1)
Distribution board designation DB 3 Lighting +Power	No of phases 1
	Nominal Voltage 400 V
	Overcurrent protective device for the distribution circuit Type BS(EN) 60898 MCB C
	Rating 63 A
	Associated RCD (if any) BS(EN) N/A
	RCD No of Poles N/A
	RCD Rating N/A mA

Circuit number and phase	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max permitted disconnection times	Overcurrent protective device				RCD	Max permitted Zs Ω
					Live mm ²	cpc mm ²		BS(EN)	Type No	Rating A	Short circuit capacity kA	Op. current I Δ _n	
1/L1	Socket.Lady chapel	B	B	1	2.5	1.5	0.4	60898 MCB	C	20	6	30	0.87
2/L1	Socket.Adjacent	O	C	1	2.5	1.5	0.4	60898 MCB	C	16	6	30	1.09
3/L1	Lights.Porch+South tower	B	B	8	1.5	1.5	0.4	60898 MCB	C	10	6	300	1.75
4/L1	Lights.Nave north	H	C	6	1.5	11.8	0.4	60898 MCB	C	10	6	300	1.75
5/L1	Lights.Nave south	H	C	12	1.5	11.8	0.4	60898 MCB	C	10	6	300	1.75
6/L1	Lights.Sanctuary	H	C	9	1.5	11.8	0.4	60898 MCB	C	10	6	300	1.75
7/L1	Lights.Nave pendants	B	B	11	1.5	1.5	0.4	60898 MCB	C	10	6	300	1.75
8/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
9/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-
10/L1	SPARE	-	-	-	-	-	-	-	-	-	-	-	-

Wiring Code								
A	B	C	D	E	F	G	H	O
PVC/PVC cables	PVC cables in metallic conduit	PVC cables in non-metallic conduit	PVC cables in metallic trunking	PVC cables in non-metallic trunking	PVC/SWA cables	XLPE/SWA cables	Mineral insulated cables	Other

Board Tests

ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION

TEST INSTRUMENTS (SERIAL NUMBERS) USED

Zs Ω Operating times of associated RCD (if any) At I Δ_n ms
 Ipf kA At 5I Δ_n ms
 Correct supply polarity confirmed Phase sequence confirmed (where appropriate)

Earth fault loop impedance RCD
 Insulation resistance Other
 Continuity Other

Details of circuits and/or equipment vulnerable to damage

All fixed and portable equipment were disconnected before testing

Circuit Tests

Circuit number and phase	Circuit Impedances Ω					Insulation resistance				polar i t y	Maximum measured earth fault loop impedance Ω	RCD operating times			Remarks see continuation sheet
	Ring final circuits only (measure end to end)			All circuits (At least one column to be completed)		Live/Live	Live/Neutral	Live/Earth	Earth/Neutral			At I Δ _n	At 5I Δ _n	Test button operation	
	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	(R ₁ + R ₂)	(R ₂)	MΩ	MΩ	MΩ	MΩ			ms	ms		
1/L1	N/A	N/A	N/A	0.18	N/A	N/A	20	20	20	✓	0.46	18	8	✓	NO
2/L1	N/A	N/A	N/A	0.02	N/A	N/A	200	200	200	✓	0.30	18	8	✓	NO
3/L1	N/A	N/A	N/A	2.68	N/A	N/A	2	2	2	✓	2.96	18	8	✓	NO
4/L1	N/A	N/A	N/A	0.59	N/A	N/A	2	2	2	✓	0.87	197	N/A	✓	NO
5/L1	N/A	N/A	N/A	0.93	N/A	N/A	2	2	2	✓	1.21	197	N/A	✓	NO
6/L1	N/A	N/A	N/A	0.81	N/A	N/A	2	2	2	✓	1.09	197	N/A	✓	NO
7/L1	N/A	N/A	N/A	1.24	N/A	N/A	2	2	2	✓	1.52	197	N/A	✓	NO
8/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
9/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
10/L1	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By

Signature

Position

Name

Date of testing

Board Details		TO BE COMPLETED IN EVERY CASE	ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION	
Location of Distribution Board	Toilet block cupboard.	Supply to distribution board is from	SubMains(DB 1 Main, 5/L3/L3)	
Distribution board designation	DB 4 Kitchen+Toilet	No of phases	1	Nominal Voltage 230 V
		Overcurrent protective device for the distribution circuit		
		Type BS(EN)	60898 MCB C	Rating 50 A
		Associated RCD (if any)	BS(EN) 4293 RCD	
			RCD No of Poles N/A	
			RCD Rating 30 mA	

Circuit number and phase	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max permitted disconnection times	Overcurrent protective device				RCD		Max permitted Zs Ω
					Live mm ²	cpc mm ²		BS(EN)	Type No	Rating A	Short circuit capacity kA	Op. current I Δn		
													1/L3	
2/L3	Ring circuit	C	B	5	2.5	1.5	0.4	60898 MCB	B	32	6	30	1.09	
3/L3	Hand wash.(Toilets)	C	B	1	2.5	1.5	0.4	60898 MCB	B	16	6	30	2.18	
4/L3	Lights	C	B	3	1	1	0.4	60898 MCB	B	6	6	30	5.82	
5/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-	
6/L3	SPARE	-	-	-	-	-	-	-	-	-	-	-	-	

Wiring Code								
A	B	C	D	E	F	G	H	O
PVC/PVC cables	PVC cables in metallic conduit	PVC cables in non-metallic conduit	PVC cables in metallic trunking	PVC cables in non-metallic trunking	PVC/SWA cables	XLPE/SWA cables	Mineral insulated cables	Other

Board Tests

ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION						TEST INSTRUMENTS (SERIAL NUMBERS) USED					
Zs	0.33	Ω	Operating times of associated RCD (if any)	At I Δ _n	197	ms	Earth fault loop impedance	100710/4745	RCD	100710/4745	
Ipf	0.70	kA		At 5I Δ _n	N/A	ms		Insulation resistance	100710/4745	Other	N/A
Correct supply polarity confirmed	<input checked="" type="checkbox"/>	Phase sequence confirmed (where appropriate)	N/A			Continuity			100710/4745	Other	N/A

Details of circuits and/or equipment vulnerable to damage

All fixed and portable equipment were disconnected before testing.

Circuit Tests

Circuit number and phase	Circuit Impedances Ω					Insulation resistance				polarity	Maximum measured earth fault loop impedance Ω	RCD operating times			Remarks see continuation sheet
	Ring final circuits only (measure end to end)			All circuits (At least one column to be completed)		Live/Live	Live/Neutral	Live/Earth	Earth/Neutral			At I Δ _n	At 5I Δ _n	Test button operation	
	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	(R ₁ + R ₂)	(R ₂)	MΩ	MΩ	MΩ	MΩ			ms	ms		
1/L3	N/A	N/A	N/A	0.39	N/A	N/A	200	200	200	✓	0.72	35	20	✓	NO
2/L3	0.21	0.21	0.30	0.52	N/A	N/A	200	200	200	✓	0.85	35	20	✓	NO
3/L3	N/A	N/A	N/A	0.51	N/A	N/A	200	200	200	✓	0.84	35	20	✓	NO
4/L3	N/A	N/A	N/A	0.69	N/A	N/A	200	200	200	✓	1.02	35	20	✓	NO
5/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
6/L3	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By

Signature	<input type="text"/>	Position	Qualifying supervisor
Name	T.GILLMAN	Date of testing	16/08/2018

Board Details	
TO BE COMPLETED IN EVERY CASE	ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION
Location of Distribution Board Tower.	Supply to distribution board is from SubMains(DB 1 Main, 5/L2/L2)
Distribution board designation DB 5 Tower cupboard.	No of phases 1 Nominal Voltage 230 V Overcurrent protective device for the distribution circuit Type BS(EN) 60898 MCB C Rating 20 A
	Associated RCD (if any) BS(EN) N/A RCD No of Poles N/A RCD Rating N/A mA

Circuit Details														
Circuit number and phase	Circuit designation	Type of wiring	Reference method	No of points served	Circuit conductors csa		Max permitted disconnection times	Overcurrent protective device				RCD		Max permitted Zs Ω
					Live mm ²	cpc mm ²		BS(EN)	Type No	Rating A	Short circuit capacity kA	Op. current I Δn		
1/L2	Sockets.Tower	B	B	4	2.5	1.5	0.4	61009 RCD/RCBO	C	16	10	30	1.09	
2/L2	Fishermans store	O	C	2	2.5	1.5	0.4	61009 RCD/RCBO	C	20	10	30	0.87	
3/L2	Socket.Adjacent	C	B	1	2.5	1.5	0.4	61009 RCD/RCBO	C	16	10	30	1.09	
4/L2	Lights.Tower	B	B	6	1.5	82.6	0.4	60898 MCB	C	16	10	300	1.09	
5/L2	Lights.Cupboards	O	C	3	1.5	1	0.4	60898 MCB	C	6	10	300	2.91	
6/L2	Light.Tower door	B	B	1	1.5	1.5	0.4	60898 MCB	C	6	10	300	2.91	
7/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-	
8/L2	SPARE	-	-	-	-	-	-	-	-	-	-	-	-	

Wiring Code								
A	B	C	D	E	F	G	H	O
PVC/PVC cables	PVC cables in metallic conduit	PVC cables in non-metallic conduit	PVC cables in metallic trunking	PVC cables in non-metallic trunking	PVC/SWA cables	XLPE/SWA cables	Mineral insulated cables	Other

Board Tests		TEST INSTRUMENTS (SERIAL NUMBERS) USED	
ONLY TO BE COMPLETED IF THE DISTRIBUTION BOARD IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION			
Zs	0.74 Ω	Operating times of associated RCD (if any)	At I Δ _n 197 ms
Ipf	0.31 kA		At 5I Δ _n N/A ms
Correct supply polarity confirmed	<input checked="" type="checkbox"/>	Phase sequence confirmed (where appropriate)	N/A
Earth fault loop impedance	100710/4745	RCD	100710/4745
Insulation resistance	100710/4745	Other	N/A
Continuity	100710/4745	Other	N/A

Details of circuits and/or equipment vulnerable to damage

All fixed and portable equipment were disconnected before testing.

Circuit number and phase	Circuit Impedances Ω					Insulation resistance				polar i t y	Maximum measured earth fault loop impedance Ω	RCD operating times			Remarks see continuation sheet
	Ring final circuits only (measure end to end)			All circuits (At least one column to be completed)		Live/ Live	Live/ Neutral	Live/ Earth	Earth/ Neutral			At I Δ _n	At 5I Δ _n	Test button operation	
	r ₁ (Line)	r _n (Neutral)	r ₂ (cpc)	(R ₁ + R ₂)	(R ₂)										
1/L2	N/A	N/A	N/A	0.52	N/A	N/A	200	200	200	✓	1.26	18	8	✓	NO
2/L2	N/A	N/A	N/A	0.60	N/A	N/A	200	200	200	✓	1.34	18	8	✓	NO
3/L2	N/A	N/A	N/A	0.02	N/A	N/A	200	200	200	✓	0.76	18	8	✓	NO
4/L2	N/A	N/A	N/A	1.44	N/A	N/A	200	200	200	✓	2.18	197	N/A	✓	NO
5/L2	N/A	N/A	N/A	0.43	N/A	N/A	200	200	200	✓	1.17	197	N/A	✓	NO
6/L2	N/A	N/A	N/A	0.16	N/A	N/A	200	200	200	✓	0.90	197	N/A	✓	NO
7/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
8/L2	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

Tested By

Signature	[Signature Box]	Position	Qualifying supervisor
Name	T.GILLMAN	Date of testing	16/08/2018

Extent of Electrical Installation covered by this report, Continued. from page 1

100% Insulation test.
75% Full test of individual circuits.
20% Inspection of fittings and accessories.

Agreed limitations including the reasons, Continued. from page 1

testing therefore are not part of the test.

General condition of the installations (In terms of electrical safety), Continued. from page 1

ALL NECESSARY REMEDIAL WORKS WERE CARRIED OUT PRIOR TO THE COMPLETION OF THE TEST.

CONDITION REPORT GUIDANCE NOTES FOR RECIPIENTS

This report is an important and valuable document which should be retained for future reference.

1. The purpose of this Condition Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).
2. The person ordering the Report should have received the "original" Report and the inspector should have retained a duplicate.
3. The "original" Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner /occupier with details of the condition of the electrical installation at the time the Report was issued.
4. Where the installation incorporates residual current devices (RCD) there should be a notice at or near the device stating that it should be tested quarterly. **For safety reasons it is important that this instruction is followed.**
5. Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
6. Some operational limitations such as such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.
7. For items classified in Section K as C1 ("Danger Present"), **the safety of those using the installation is at risk**, and it is recommended that a skilled person competent in electrical installation work undertakes the necessary remedial work immediately.
8. For items classified in Section K as C2 ("Potentially Dangerous"), the safety of those using the installation may be at risk and it is recommended that a competent person undertakes the necessary remedial work as a matter of urgency.
9. Where it has been stated in Section K that an observation requires further investigation (code F1) the inspection has revealed an apparent deficiency which may result in a code C1 or C2, and could not, due to the extent or limitations of the inspection, be fully identified could not, due to the extent or limitations of this inspection, be fully identified. Such observations should be investigated without delay. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).
10. For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The recommended date by which the next inspection is due is stated in Section F of the Report under 'Recommendations' and on a label at or near to the consumer unit / distribution board.