

This inspection is for gas safety purposes only to comply with the Gas Safety (Installation and Use) Regulations. Flues have been inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.

REGISTERED BUSINESS DETAILS Reg No: 525389

Gas Engineer: CHRIS SKUDDER
 Gas Safe registered engineer No: 4196783
 Company: WESTLANDS HEATING LTD
 Address: 287-291 CLEETHORPE RD
 GRIMSBY
 Postcode: DN31 3BH Tel: 01472 505050

INSPECTION/INSTALLATION ADDRESS

Name & Title:
 Address: ST MICHAELS CHURCH
 62 GREAT COATES RD
 GRIMSBY.
 Postcode: DN34 4ND Tel:
 Rented: Yes: No:

LANDLORD (OR AGENT) NAME & ADDRESS (if applicable)

Name & Title:
 Address:
 Postcode: Tel:

DESCRIPTION OF WORK CARRIED OUT

New Boilers Fitted

APPLIANCE DETAILS				FLUE TESTS				INSPECTION DETAILS								
Location	Make and Model	Type	Operating pressure in boiler or heat input kW/h or Btu/h	Safety device(s) correct operation Yes/No/NA	Spillage test Pass/Fail/NA	Smoke pellet flue flow test Pass/Fail/NA	Initial combustion analyser reading	Final combustion analyser reading	Satisfactory termination Yes/No/NA	Flue visual condition Pass/Fail/NA	Adequate ventilation Yes/No/NA	Landlord's appliance Yes/No/NA	Inspected Yes/No	Appliance serviced Yes/No	Appliance Safe to Use Yes/No	
1 STORE ROOM	WORCESTER GREENSTAR 40	BOILER RS	17MBK	YES	N/A	N/A	0.0006	0.0006	YES	PASS	YES	NO	YES	NO	YES	
2 STORE ROOM	WORCESTER GREENSTAR 40	BOILER RS	17MBL	YES	N/A	N/A	0.0007	0.0007	YES	PASS	YES	NO	YES	NO	YES	
3																
4																
5																

Gas Installation Pipework: Satisfactory Visual Inspection: Yes No

Emergency Control Accessible: Yes No

Satisfactory Gas Tightness Test: Yes No

Equipotential Bonding Satisfactory: Yes No

GIVE DETAILS OF ANY FAULTS

RECTIFICATION WORK CARRIED OUT

No	Description of Fault	Rectification Work Carried Out	WARNING NOTICE ISSUED Yes/No/NA	WARNING TAG or STICKER FIXED Yes/No/NA
1				
2				
3				
4				
5				

Audible CO Alarms: Approved CO Alarms Fitted: Yes No N/A

Are CO Alarms in Date: Yes No N/A

Testing of CO Alarms Satisfactory: Yes No N/A

Smoke Alarms Fitted: Yes No N/A

Number of appliances tested: 2

This record is issued by: *[Signature]* Print Name: C. SKUDDER

Date: 18-09-18