

MINOR ELECTRICAL INSTALLATION WORKS

To be used only for minor electrical work which does not include the provision of a new circuit

Certificate Reference:

1 DESCRIPTION OF THE MINOR WORKS

Client address:	Mrs E Betts Watling Street, Witherley	Installation address:	St Peters Church Witherley, Atherstone, CV9 3NA
Description of the minor works: To replace existing porch light			
Details of departures, if any, from BS 7671:2018 for the circuit altered or extended (Regulation 120.3, 133.1.3 and 133.5): Where applicable, a suitable risk assessment(s) must be attached to the Certificate. None			
Date minor works completed:	15/01/2019	Risk assessment attached:	N/A
Comments on (including any defects observed in) the existing installation (Regulation 644.1.2): Good			

2 PRESENCE AND ADEQUACY OF INSTALLATION EARTHING AND BONDING ARRANGEMENTS

System type and earthing arrangements:	TN-C-S <input checked="" type="checkbox"/>	TN-S <input type="checkbox"/>	TT <input type="checkbox"/>
	N/A	N/A	N/A
Earth fault loop impedance at distribution board (Zdb) supplying the final circuit:	1.04 Ω		
Presence of adequate main protective conductors:	Earthing Conductor <input checked="" type="checkbox"/>		
Main protective bonding conductor(s) to:	Water <input checked="" type="checkbox"/>	Gas <input type="checkbox"/>	Oil <input type="checkbox"/>
	N/A	N/A	Structural Steel <input type="checkbox"/>
			Other: <input type="checkbox"/>
			N/A

3 CIRCUIT DETAILS

D.B. Designation:	D.B. 1	D.B. Location and Type:	Main isle
Circuit Number:	LIM	Circuit Description:	Lighting supply
Circuit overcurrent protective device:	BS (EN):	3871 MCB	Type: 2 Rating: 10 A
Maximum disconnection time permitted by BS 7671:	5 s	Conductor sizes:	Live: 1.5 mm ² cpc: 1.0 mm ²

4 TEST RESULTS FOR THE CIRCUIT ALTERED OR EXTENDED

Protective conductor continuity:	R1 + R2: 0.8 Ω	or R ₂ : N/A Ω	
Continuity of ring final circuit conductors:	L/L: N/A Ω	N/N: N/A Ω cpc/cpc: N/A Ω	
Insulation resistance:	Live - Live: > 200MΩ	Live - Earth: > 200 MΩ	
Polarity satisfactory:	<input checked="" type="checkbox"/>	Maximum measured earth fault loop impedance, Zs: 1.04 Ω	
RCD operation: Rated residual operating current (I _n):	N/A mA	Disconnection time: N/A ms	
Instruments Used (Serial Numbers):		Satisfactory test button operation: <input checked="" type="checkbox"/>	
Multi-functional:	14011043	Insulation resistance:	14011043
Earth electrode resistance:	14011043	Continuity:	14011043
		Earth fault loop impedance:	14011043
		RCD:	14011043

5 DECLARATION

I/we CERTIFY that the said works do not impair the safety of the existing installation, that the said works have been designed, constructed, inspected and tested in accordance with BS 7671:2018 (IET Wiring Regulations), amended to 2018, and that the said works, to the best of my/our knowledge and belief, at the time of my/our inspection, complied with BS 7671 except as detailed in Section 1 above.

Trading Title:	Kare Services		
Address:	5 Church Road Witherley Atherstone	Registration Number (if applicable):	NAPIT 12345
	Postcode: CV9 3NA	Telephone Number:	01827717567
Name:	Stuart Liggins	Position:	Electrician
Signature:	<i>M.S. Liggins</i>	Date:	15/01/2019

MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE GUIDANCE FOR RECIPIENTS

(to be appended to the Certificate)

This Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with British Standard 7671 (the IET Wiring Regulations).

You should have received an 'original' Certificate and the contractor should have retained a duplicate. If you were the person ordering the work, but not the owner of the installation, you should pass this Certificate, or a copy of it, to the owner. A separate Certificate should have been received for each existing circuit on which minor works have been carried out. This Certificate is not appropriate if you requested the contractor to undertake more extensive installation work, for which you should have received an Electrical Installation Certificate.

The Certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Certificate will demonstrate to the new owner that the minor electrical installation work carried out complied with the requirements of British Standard 7671 at the time the Certificate was issued.