

Attention of Richard Dixon

21 Mill Close
Sapcote
Leicester
LE9 4FW

1 March 2018

KH/11985

Dear Richard

All Saint's Church, Sapcote

I confirm that we undertook surface water drainage investigations on 17 Feb 2018 in the churchyard following inconclusive CCTV survey by County Drains earlier in the month.

It was found that the main drain on north side of churchyard is blocked. We have prepared more detailed drawings and specification to resolve this for consideration.

We trust this is satisfactory and await your further instructions.

Yours sincerely



Keith Hamilton
For and on behalf of
DarntonB3 Architecture

ARCHITECTURE
PROJECT MANAGEMENT
MASTER PLANNING
URBAN DESIGN
LANDSCAPE DESIGN
SPACE PLANNING
INTERIOR DESIGN
MECHANICAL & ELECTRICAL
CDM ADVISORS
PRINCIPAL DESIGNERS

Suite C, Loughborough
Technology Centre,
Epinal Way,
Loughborough,
Leicestershire
LE11 3GE

T 01509 610510
F 01509 211510

www.darntonB3.com

OFFICES ALSO AT:

LONDON
LEEDS
CARDIFF
ABERYSTWYTH
NEWTOWN
MANCHESTER
BRADFORD
GLASGOW



CHARTERED ARCHITECTS

DIRECTORS:

A HAMILTON
MAPM (CPM)

D SUGGITT
Dip Arch ARIBA HonRCM APS

K HARDCASTLE
BSc(Hons) MRICS MCIQB MCIAT

C RYAN
B Arch (Hons) MSc RIBA APS

A LODGE
BA (Hons) Dip M

R CAMPBELL-PILLING
BA Hons Int Des. Dipl

DYFRIG JONES
Dip Arch RIBA ARB

SIMON TURNER
ACIOB MAPM

PAUL DAVIES
FCA

DarntonEGS Ltd
Registered Address:
The Coach House
Hank Fryson
Leeds LS25 5DU
Company Registration: 06617944

Licensed to BS 9001