



Electrical Certificate Installation/Modification

Requirements for Electrical Installations - BS 7671:2018
(IET Wiring Regulations 18th Edition)

Information for recipients:

This safety Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with BS 7671 (the IET Wiring Regulations).

You should have received an original Certificate and the contractor should have retained a duplicate.

If you were the person ordering this work, but not the owner of the installation, you should pass this Certificate, or a copy of it, immediately to the owner. The original Certificate is to be retained in a safe place and be shown to any person inspecting or undertaking work on the electrical installation in the future.

If you later vacate the property, this Certificate will demonstrate to the new owner that the electrical installation complied with the requirements of BS 7671 at the time the Certificate was issued.

The Construction (Design and Management) Regulations require that, for a project covered by those regulations, a copy of this certificate, together with schedules, is included in the project health and safety document.

For safety reasons, the electrical installation will need to be re-inspected at appropriate intervals by a skilled person or persons, competent in such work. The maximum time interval recommended before the next inspection is stated on Page 2 under "NEXT INSPECTION".

This Certificate is intended to be issued only for a new electrical installation or for new work associated with an addition or alteration to an existing installation. It should not have been issued for the inspection and testing of an existing electrical installation. An "Electrical installation Condition Report" should be issued for such an inspection.

This Certificate is only valid if accompanied by the schedule of inspections and the schedule(s) of test results.



Electrical Certificate Installation/Modification

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

NA/ 1 9 2 3 3 0 0 0 0 1 0 5 9

EIC

Page 2 of 8

1 Details of the Installation

Client	St Leonards Church	Installation	
Address	St. Leonards Church Streatham High Road London	Address	St. Leonards Church Streatham High Road London
Postcode	SW16 1HS	Postcode	SW16 1HS

2 Description, extent and limitations of the installation (note 5)

Installation is New Addition Alteration Records Available Yes No Date of original installation approx 1984

Description of the installation
New final circuits with CPC from existing DB wired through existing conduit/trunking

Extent of the installation covered by this certificate
New lighting and power circuits from Lighting DB

Details of departures from BS 7671 (regulations 120.3, 133.1.3 and 133.5)

Details of permitted exception. (regulation 411.3.3) where applicable a suitable risk assessment(s) must be attached to this certificate

RCD Risk assessment attached (Non Dwelling ONLY)

3 Declaration For design, construction, inspection and testing (for sole person responsibility)

I being the person responsible for design, construction, inspection and the test of the electrical installation (as indicated by my signature below), particulars of which are described in Section 2, having exercised reasonable skill and care when carrying out the design, construction, inspection and test hereby CERTIFY that the design, construction, inspection and test for which I have been responsible is to the best of my knowledge and belief in accordance with BS 7671:2018, amended to 2020

The extent of liability of the signatory or the signatories is limited to work described in Section 2 as subject of this certificate.

For the DESIGN / CONSTRUCTION / INSPECTION & TEST of the installation:

Company	Avo Solar Limited	Signature	
Inspector Name	Andrew Henery	Position	director
Address	Pipers Business Centre 220 Vale Road TONBRIDGE, Kent TN9 1SP	Date	03/11/2020
		Member No.	19233

Next inspection I the designer recommend that this installation is further inspected after an interval of not more than 5 years

4 Supply characteristics and earthing arrangements

Earthing Arrangements TN-S TN-C-S TT Other If Other please specify N/A

Number & Type of live conductors AC DC No. of phases 3 No. of wires 4

Nature of Supply Parameters (Note: ⁽¹⁾ by enquiry, ⁽²⁾ by enquiry or by measurement)

Nominal voltage, U/U₀ ⁽¹⁾ 230/400 v Nominal frequency, f⁽¹⁾ 50 Hz Confirmation of polarity

Prospective fault current, I_{pr} ⁽²⁾ 2.71 kA External loop impedance, Z_e ⁽²⁾ 0.09 Ω Or Z_{db} Source of Circuit 0.09

Supply Protective Device BS (EN) 1361 Type 2 Rated Current N/V A

Other Sources of Supply (as detailed on attached schedule) N/A

5 Particulars of installation referred to in this certificate

Details of installation Earth Electrode (where applicable) Type (e.g. rod(s), tape etc)

Location Electrode resistance to earth Ω Distributors facility Installation Earth Electrode

Main Protective Conductors	Material	csa	(✓) or Value	Maximum Demand (load)	Amps	KVA
Earthing Conductor	Copper	25	Ω (connection / continuity) (✓) or Value	100	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Protective Bonding Conductor (to extraneous-conductive-parts)	Copper	16	Ω (connection / continuity) (✓) or Value			
Main Supply Conductor	Copper	35				

Water installation Ω To structural steel Ω

Gas installation pipes Ω To lightning protection Ω

Oil installation pipes Ω Other Ω

Main Switch Location DB in cupboard adj. church office

Fuse/device rating or setting N/A A Voltage rating 400 V BS(EN) 60947-3 No. of Poles 3 Current Rating 100 A



If RCD main switch: Rated residual operating current I_{Δn} N/A mA Rated time delay N/A ms Measured operating trip time ms















































Comments on existing installation (in case of addition or alteration see section 644.1.2) use continuation sheet if needed

Existing installation installed approx 1984 using steel conduit / trunking as cpc on final circuits.

(For additions or alterations) cables concealed within trunking and conduits, or cables or conduits concealed under floors, in roof spaces and generally within the fabric of the building or underground may not have been inspected.

Outcomes

Indicates an inspection has been carried out and the result is satisfactory		Indicates the inspection is not applicable to a particular item	
---	---	---	---

Item No.	Description	Outcome
1.0 External Condition Of Intake Equipment (Visual Inspection Only) Where inadequacies are encountered, it is recommended that the person ordering the report informs the appropriate authority		
1.1	Service cable	
1.2	Service head	
1.3	Earthing arrangement	
1.4	Meter tails	
1.5	Metering equipment	
1.6	Isolator (where present)	
2.0 Parallel Or Switched Alternative Sources Of Supply		
2.1	Adequate arrangements where a generating set operates as a switched alternative to the public supply (551.6)	
2.1.1	Dedicated earthing arrangement independent of that of the public supply (551.4.3.2.1)	
2.2	Adequate arrangements where a generating set operates in parallel with the public supply (551.7)	
2.2.1	Correct connection of generator in parallel (551.7.2)	
2.2.2	Compatibility of characteristics of means of generation (551.7.3)	
2.2.3	Means to provide automatic disconnection of generator in the event of loss of public supply system or voltage or frequency deviation beyond declared values (551.7.4)	
2.2.4	Means to prevent connection of generator in the event of loss of public supply system or voltage or frequency deviation beyond declared values (551.7.5)	
2.2.5	Means to isolate generator from the public supply system (551.7.6)	
3.0 Automatic Disconnection Of Supply		
3.1	Protective earthing/bonding arrangements (411.3; Chap 54)	
3.2.1	Distributor's earthing arrangement (542.1.2.1; 542.1.2.2) or installation earth electrode arrangement (542.1.2.3)	
3.2.2	Earthing conductor and connections (Section 526; 542.3; 542.3.2; 543.1.1)	
3.2.3	Main protective bonding conductors and connections (Section 526; 544.1; 554.1.2)	
3.2.4	Earthing bonding labels at all appropriate locations (514.13)	
3.3.1	Earthing conductor connections	
3.3.2	All protective bonding connections (543.3.2)	
3.4	FELV - requirements satisfied (411.7; 411.7.1)	
4.0 Other Methods Of Protection (Where any of the methods listed below are employed details should be provided on separate sheets)		
4.1.1	SELV (Section 414)	
4.1.2	PELV (Section 414)	
4.1.3	Double insulation (Section 412)	
4.1.4	Reinforced insulation (Section 412)	
4.2.1	Insulation of live parts (416.1)	
4.2.2	Barriers or enclosures (416.2; 416.21)	
4.2.3	Obstacles (Section 417; 417.2.1; 417.2.2)	
4.2.4	Placing out of reach (Section 417; 417.3)	
4.3.1	Non-conducting location (418.1)	
4.3.2	Earth-free local equipotential bonding (418.2)	
4.3.3	Electrical separation (Section 415; 415.2)	
4.4.1	RCDs not exceeding 30 mA as specified (415.1)	
4.4.2	Supplementary bonding (Section 415; 415.2)	
5.0 Distribution Equipment		
5.1	Security of fixing (134.1.1)	
5.2	Insulation of live parts not damaged during erection (416.1)	
5.3	Adequacy/security of barriers (416.2)	
5.4	Suitability of enclosure(s) for IP and fire rating (416.2; 421.1.6; 421.1.201;526.5)	
5.5	Enclosure not damaged during installation (134.1.1)	
5.6	Presence and effectiveness of obstacles (417.2)	
5.7	Components are suitable according to manufacturers' assembly instructions or literature (536.4.203)	
5.8	Presence of main switch(es), linked where required (462.1.201)	
5.9	Operation of main switch(es) (functional check) (643.10)	
5.10	Manual operation of circuit-breakers and RCDs to prove functionality (643.10)	
5.11	Confirmation that integral test button/switch causes RCDs to trip when operated (functional check) (643.10)	



Electrical Certificate Installation/Modification Inspection Schedule

for Industrial/Commercial Premises

Requirements for Electrical Installations - BS 7671:2018 (IET Wiring Regulations 18th Edition) All items inspections to confirm as appropriate, compliance with the relevant clauses in BS 7671:2018

NA/ 1 9 2 3 3 0 0 0 0 1 0 5 9
EIC Page 4 of 8

5.12	RCDs provided for fault protection where specified (411.4.204; 411.5.2; 531.2)	✓
5.13	RCDs provided for additional protection where specified (415.1)	✓
5.14	Confirmation overvoltage protection (SPDs) provided where specified (534.4.1.1)	NA
5.15	Presence of RCD six-monthly test notice at or near the origin (514.12.2)	✓
5.16	Presence of diagrams, charts or schedules at or near each distribution board, where required (514.9.1)	✓
5.17	Presence of non-standard (mixed) cable colour warning notice at or near the appropriate distribution board, where required (514.14)	✓
5.18.1	The origin	NA
5.18.2	The meter position, if remote from the origin	✓
5.18.3	The distribution board to which the alternative/additional sources are connected	NA
5.18.4	All points of isolation of ALL sources of supply	NA
5.19	Presence of next inspection recommendation label (514.12.1)	✓
5.20	Presence of other required labelling (Section 514)	✓
5.21	Selection of protective device(s) and base(s); correct type and rating(411.3.2; 411.4; 411.4.5; 411.4.6; Sections 432; 433; 434)	✓
5.22	Single-pole protective devices in line conductors only (132.14.1; 530.3.3; 643.6)	✓
5.23	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11)	✓
5.24	Protection against electromagnetic effects where cables enter ferromagnetic enclosures (521.5.1)	✓
5.25	Confirmation that ALL conductor connections, including connections to busbars, are correctly located in terminals and are tight and secure (526.1)	✓

6.0 Final Circuits



6.1	Identification of conductors (514.3.1)	✓
6.2	Cables correctly supported throughout their run (521.10.202; 522.8.5)	✓
6.3	Examination of cables for signs of mechanical damage during installation (522.6.1; 522.8.1; 522.8.3)	✓
6.4	Examination of insulation of live parts, not damaged during erection (522.6.1; 522.8.1)	✓
6.5	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)	✓
6.6	Suitability of containment systems (including flexible conduit) (Section 522)	✓
6.7	Correct temperature rating of cable insulation (522.1.1; Table 52.1)	✓
6.8	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)	✓
6.9	Adequacy of protective devices: type and rated current for fault protection (411.3)	✓
6.10	Presence and adequacy of circuit protective conductors (411.3.1; 543.1)	✓
6.11	Co-ordination between conductors and overload protective devices (433.1; 533.2.1)	✓
6.12	Wiring systems and cable installation methods/practices with regard to the type and nature of installation and external influences (Section 522)	✓
6.13	Cables concealed under floors, above ceilings, in walls/partitions, adequately protected against damage (522.6.201; 522.6.202; 522.6.203; 522.6.204)	✓
6.14	Provision of additional protection by RCDs having rated residual operating current not exceeding 30 mA	✓
6.14.1	For all socket-outlets of rating (32 A) or less, unless exempt (411.3.3)	✓
6.14.2	Supplies for mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	NA
6.14.3	For cables concealed in walls at a depth of less than 50mm (522.6.202, 522.6.203)	✓
6.14.4	For cables concealed in walls/partitions containing metal parts regardless of depth (522.6.202, 522.6.203)	✓
6.14.5	Circuits supplying luminaires within domestic (household) premises (411.3.4)	✓
6.15	Provision of fire barriers, sealing arrangements so as to minimize the spread of fire (Section 527)	✓
6.16	Band II cables segregated/separated from Band I cables (528.1)	NA
6.17	Cables segregated/separated from non-electrical services (528.3)	✓
6.18.1	Connections under no undue strain (522.8.5; 526.6)	✓
6.18.2	No basic insulation of a conductor visible outside enclosure (526.8)	✓
6.18.3	Connections of live conductors adequately enclosed (526.5)	✓
6.18.4	Adequately connected at point of entry to enclosure (glands, bushes etc) (522.8.5)	✓
6.19	Suitability of circuit accessories for external influences (512.2)	✓
6.20	Circuit accessories not damaged during erection (134.1.1)	✓
6.21	Single-pole devices for switching or protection in line conductors only (132.14.1; 530.3.3; 643.6)	✓
6.22	Adequacy of connections, including CPCs, within accessories and at fixed and stationary equipment (Section 526)	✓

Inspector's Name: Andrew Henery

Signature: *Andrew Henery*

Date: 03/11/2020

Outcomes

Indicates an inspection has been carried out and the result is satisfactory		Indicates the inspection is not applicable to a particular item	
---	---	---	---

DB Ref: DB1

DB Location: Cupboard adjacent office

Item No.	Description	Outcome
1.0 CONSUMER UNIT/DISTRIBUTION BOARD		
1.1	Adequacy of access and working space for items of electrical equipment including switch gear (132.12)	
1.2	Components are suitable according to assembly manufacturer's instructions or literature(536.4.203)	
1.3	Presence of linked main switch(es) (462.1.201)	
1.4	Isolators, for every circuit or group of circuits and all items of equipment (462.2)	
1.5	Suitability of enclosure(s) for IP and fire ratings (416.2; 421.1.16; 421.1.201; 526.5)	
1.6	Protection against mechanical damage where cables enter equipment (522.8.1; 522.8.5; 522.8.11)	
1.7	Confirmation that ALL conductor connections are correctly loaded in terminals and are tight and secure (526.1)	
1.8	Avoidance of heating effects where cables enter ferromagnetic enclosures e.g. steel (521.5)	
1.9	Selection of correct type and ratings of circuit protective devices for overcurrent and fault protection (411.3.2; 411.4, 411.5, 411.6; Sections 432, 433; 537.3.1.1)	
1.10.1	Provision of circuit charts/schedules or equivalent forms of information (514.9)	
1.10.2	Warning notice of method of isolation where live parts not capable of being isolated by a single device (514.11)	
1.10.3	Periodic inspection and testing notice (514.12.1)	
1.10.4	RCD six-monthly test notice; where required (514.12.2)	
1.10.5	AFDD six-monthly test notice; where required	
1.10.6	Warning notice of non-standard (mixed) colours of conductors present (514.14)	
1.11	Presence of labels to indicate the purpose of switch gear and protective devices (514.1.1; 514.8)	
2.0 FINAL CIRCUITS		
2.1	Adequacy of conductors for current-carrying capacity with regard to the type and nature of installation (Section 523)	
2.2	Cable installation methods suitable for the location(s) and external influences (Section 522)	
2.3	Segregation/separation of Band I (ELV) and Band II (LV) circuits, and electrical and non-electrical services (528)	
2.4	Cables correctly erected and supported throughout, with protection against abrasion (Sections 521, 522)	
2.5	Provision of fire barriers, ceiling arrangements where necessary (527.2)	
2.6	Non-sheathed cables enclosed throughout in conduit, ducting or trunking (521.10.1; 526.8)	
2.7	Cables concealed under floors, above ceilings or in walls/partitions, adequately protected against damage (522.6.201, 202, 203, 204)	
2.8	Conductors correctly identified by colour, lettering or numbering (Section 514)	
2.9	Presence, adequacy and correct termination of protective conductors (411.3.1.1; 543.1)	
2.10	Cables and conductors correctly connected, enclosed and with no undue mechanical strain (Section 526)	
2.12	Single-pole devices for switching or protection in line conductors only (132.14.1; 530.3.3, 643.6)	
2.13	Accessories not damaged, securely fixed, correctly connected, suitable for external influences (134.1.1; 512.2; Section 526)	
2.14.1	Socket-outlets rated at 32 A or less, unless exempt (411.3.3)	
2.14.2	For the supply of mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)	
2.14.3	Cables concealed in walls at a depth of less than 50 mm (522.6.202; 522.6.203)	
2.14.4	Cables concealed in walls/partitions containing metal parts regardless of depth (522.6.202; 522.6.203)	
2.14.5	Final circuits supplying luminaires within domestic (household) premises (411.3.4)	
2.15.1	Means of switching off for mechanical maintenance (Section 644; 537.3.2)	
2.15.2	Emergency switching (465.1; 537.3.3)	
2.15.3	Functional switching, for control of parts of the installation and current-using equipment (463.1; 437.3.1)	
2.15.4	Firefighter's switches (537.4)	
3.0 CURRENT-USING EQUIPMENT (PERMANENTLY CONNECTED)		
3.1	Equipment not damaged, securely fixed and suitable for external influences (134.1.1; 416.2; 512.2)	
3.2	Provision of overload and/or undervoltage protection e.g. for rotating machines, if required (Sections 445, 552)	
3.3	Installed to minimize the build-up of heat and restricts the spread of fire (421.1.4; 559.4.1)	
3.4	Adequacy of working space. Accessibility to equipment (132.12; 513.1)	
4.0 LOCATION(S) CONTAINING A BATH OR SHOWER (SECTION 701)		
4.1	30 mA RCD protection for all LV circuits, equipment suitable for the zones, supplementary bonding (where required) etc.	
5.0 OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS		
5.1	List all other special installations or locations present, if any. (record separately the result of particular inspections applied)	



Electrical Certificate Installation/Modification DB Inspection Schedule

for Industrial/Commercial Premises

Requirements for Electrical Installations - BS 7671:2018 (IET Wiring Regulations 18th Edition) All items inspections to confirm as appropriate, compliance with the relevant clauses in BS 7671:2018

NA/ 1 9 2 3 3 0 0 0 0 1 0 5 9

EIC

Page 6 of 8

6.0 Schedule of Tests Results to be recorded on Schedule of Test Results

6.1	External earth loop impedance, Z_e	Yes
6.2	Installation earth electrode	N/A
6.3	Prospective fault current, Ipf	Yes
6.4	Continuity of Earth Conductors	Yes
6.5	Continuity of Circuit Protective Conductors	Yes
6.6	Continuity of ring final circuit	Yes
6.7	Continuity of Protective Bonding Conductors	Yes
6.8	Volt drop verified	Yes

6.9	Insulation Resistance between Live Conductors	Yes
6.10	Insulation Resistance between Live Conductors & Earth	Yes
6.11	Polarity (prior to energisation)	Yes
6.12	Polarity (after energisation) including phase sequence	Yes
6.13	Earth Fault Loop Impedance	Yes
6.14	RCDs / RCBOs including selectivity	Yes
6.15	Functional testing of RCD devices	Yes
6.16	Functional testing of AFDD(s) devices	N/A

Inspector's Name: A HENRY

Date: 03/11/2020

Signature: 



Electrical Certificate Installation/Modification Test Schedule

for Industrial/Commercial Premises

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th Edition)

NA 1 9 2 3 3 0 0 0 1 0 5 9
EIC Page 7 of 8

Client St Leonards Church

Installation Address Streatham High Road, London

Postcode SW16 1HS

Distribution board details - Complete in every case

Complete only if the distribution board is not connected directly to the origin of the installation

Test instrument serial number(s)

Location Cupboard adjacent office
Designation DB1
Num. of ways 4

Overcurrent protective device for the distribution circuit:
No. of phases 3
Nominal Voltage 400V
Supply polarity confirmed
Supply to distribution board is from Crypt Panel Board Type 2 BS(EN) 60947
Rating 100
Phase sequences confirmed

Characteristics at this distribution board
Associated RCD (if any): BS (EN) applicable
Operating at 1 IΔn ms Above 30mA
30mA or below 30mA or below
Operating at 5 IΔn ms
Zs 0.22 Ω No. of poles A
IΔn 1.62 kA IΔn
Time delay (if applicable)

Loop impedance 101320644
Insulation resistance 101320644
Continuity 101320644
RCD 101320644

CIRCUIT DETAILS

TEST RESULTS

Circuit No. and Line No.	Distribution board Designation	Circuit designation	Type of wiring	Ref. method	No. of points	Circuit conductors		Maximum disconnection	Overcurrent protective devices	Breaking capacity (kA)	RCD operating (mA)	BS 7671 Max. permitted Zs Other 80%	Circuit impedance Ω			All circuits to be completed using R1/R2 or R2, not both	Insulation resistance (Record lower reading)		RCD testing	Manual test button operation	
						L / N	CPC						r1	r2	r		Test voltage	L/L, L/N, M(Ω)			L/E, N/E, M(Ω)
1/L1	lights upper Gallery South		B	B	12	2.5	2.5	0.4	C 61009	10	30	1.09	N/A	0.32	500	>500	>500	27.8	27.8	AFDD	✓
1/L2	Lights upper gallery North		B	B	12	2.5	2.5	0.4	C 61009	10	30	0.87	N/A		500	>500	>500	28.3	27.9	✓	✓
1/L3	Blank												N/A							N/A	N/A
2/L1	Skts Ring South Altar		B	B	3	2.5	2.5	0.4	C 61009	10	30	1.08	✓	0.12	500	>500	>500	38.6	28.7	✓	✓
2/L2	Lighting control socket above audi		A	C	1	2.5	2.5	0.4	C 61009	10	30	1.08	N/A	0.11	500	>500	>500	38.6	28.8	✓	✓
2/L3	Blank												N/A							N/A	N/A
3/L1	Lights Altar North		B	B	5	2.5	2.5	0.4	C 61009	10	30	2.91	N/A	0.45	500	>500	>500	37.9	27.7	✓	✓
3/L2	Lights Altar South		B	B	7	2.5	2.5	0.4	C 61009	10	30	2.91	N/A	0.21	500	>500	>500	28.3	28.0	✓	✓
3/L3	Audio Desk Power		O	B	2	2.5	2.5	0.4	C 61009	10	30	2.91	N/A	0.35	500	>500	>500	38.8	28.0	✓	✓
4/L1	Lights Under Gallery North		O	B	8	2.5	2.5	0.4	C 61009	10	30	2.91	N/A	0.57	500	>500	>500	28.5	28.7	✓	✓
4/L2	Lights Under Gallery South		O	B	8	2.5	2.5	0.4	C 61009	10	30	0.87	N/A	0.50	500	>500	>500	28.5	28.7	✓	✓
4/L3	Sockets North Altar		B	B	3	2.5	2.5	0.4	C 61009	10	30	1.09	N/A	0.30	500	>500	>500	28.7	28.6	✓	✓

Details of circuits and/or installed equipment vulnerable to damage when testing Date(s) dead testing 03/11/2020 To 03/11/2020 Date(s) live testing 03/11/2020 To 03/11/2020

Tested by: Name (capital letters) A J HENRY Position Director Date 03/11/2020 Signature

Wiring Types: A PVC/PVC B PVC cables in metallic Conduit C PVC cables in non-metallic Conduit D PVC cables in metallic Trunking E PVC cables in non-metallic Trunking F PVC/SWA cables G SWA/XPLE cables H Mineral Insulated I Other Mix B + F

Created by NAPIT Online © Copyright 2021 Page 7 of 8



Electrical Certificate Installation/Modification

Requirements for Electrical Installations
BS 7671:2018 (IET Wiring Regulations 18th
Edition)

NA/ 1 9 2 3 3 0 0 0 0 1 0 5 9
EIC Page 8 of 8

Generic Continuation

Ze cannot be verified as there are systems permanently connected to panel board that cannot be disrupted. Service fuse and earthing arrangement cannot be verified, this is in a locked cupboard