

Reference Number:

AJS MINOR 391

MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE

(REQUIREMENTS FOR ELECTRICAL INSTALLATIONS - BS7671 (IET WIRING REGULATIONS))

To be used only for minor electrical work which does not include the provision of a new circuit

Details of the Minor Works

1

Description of the minor works To install 8 x new LED uplights in the nave to existing lighting circuit and replace light in North Aisle with new LED fitting.		Location/Address: Holy Cross Church, Church Street, Avening, Gloucestershire GL8 8NL	
Job Reference: -	Date completed: 02/01/2020	Client: Rev Dr G P South,	
Details of departures, if any, from BS7671: NONE Where applicable, a suitable risk assessment must be attached.			
Comments on existing installation (including any defects observed): NONE			Risk Assessment attached: N/A

Installation & Circuit Details

2

System Earthing arrangement: TN-S	Zdb: 0.74 Ω		
DB reference: DB Transept 2	Bonded services - Water: ✓	Gas: N/A	Oil: ✓
DB location & type: South Transept	Circuit no. & description: Circuit 2 - Lights Nave	Structural steel: N/A	
Protective Device: BS(EN): 60898	Type: B	Rating: 6	A Manufacturer: Wylex
Cable Type: PVC/FP200	Live csa: 1.5 mm ²	cpc csa: 1 mm ²	
Installation Method: Clipped Direct	Maximum Z _S : 5.8266 Ω		

Test Results

3

<input checked="" type="checkbox"/> Presence of adequate main earthing conductor <input checked="" type="checkbox"/> Polarity check	Ring continuity: Line: - Ω Neutral: - Ω Cpc: - Ω	Insulation Resistance: Line/Neutral: N/A MΩ Line/Earth: 15.2 MΩ Neutral/Earth: 15.2 MΩ Line/Line: - MΩ	RCD (where fitted): Test button operation: ✓ Operating current: 30 mA Operating time at I _{Δn} : 17 ms Operating time at 5I _{Δn} : 18 ms
Circuit Resistance: R1 + R2 1.86 Ω		or R2 - Ω	Earth fault loop impedance: 2.1 Ω

Declaration

4

I/We CERTIFY that the said works do not impair the safety of the existing installation, that the said works have been designed, constructed, inspected and tested in accordance with BS7671:2018 (IET Wiring Regulations), amended to 2018 (date) and that the said works, to the best of my/our knowledge and belief, at the time of my/our inspection, complied with BS7671 except as detailed in part 1 above.

Company and Address including postcode: Anthony J Smith (Gloucester) Ltd, 34 Upper mills Estate, Bristol Road, Stonehouse GL10 2BJ		Name: CHE POLLEY
		Position: QUALIFIED SUPERVISOR
		Date: 27/01/2020
CPS Provider: NICEIC	Signature: <i>ChePolley</i>	
CPS Registration No: 010621		

MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE GUIDANCE FOR RECIPIENTS

This certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed, inspected and tested in accordance with British Standard 7671 (the IET Wiring Regulations).

You should have received an 'Original' Certificate and the contractor should have retained a duplicate. If you were the person ordering the work, but not the owner of the installation, you should pass this Certificate, or a copy of it, to the owner. A separate Certificate should have been received for each existing circuit on which minor works have been carried out. This Certificate is not appropriate if you requested the contractor to undertake more extensive installation work, for which you should have received an Electrical Installation Certificate.

This Certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Certificate will demonstrate to the new owner that the minor electrical installation work carried out complied with the requirements of British Standard 7671 at the time the Certificate was issued.