

# St Mary Magdalene Huntshaw

## Report on Communication Equipment installed on tower.

Inspection                      Report  
**9 December 2022**      **6 January 2023**


Application Ref: 2018-025153  
 Church:Huntshaw: St Mary Magdalene  
 Diocese:Exeter  
 Archdeaconry:Barnstaple  
 Status:Faculty granted, awaiting Practical Completion  
 Logged By:Miss Charlotte Vickers (Fri 03 Aug 2018)  
 Summary:Installation of Broadband equipment on tower.

### 1.00 Scope and quality of work

1.01



Position of mounting pole for transmitters



Bracket fixings to parapet and pinnacle base.

1.02	Impact on the existing fabric is relatively minimal and ultimately reversable.
1.03	Cables runs are relatively short and have not been clipped to the fabric of the church but remain maintainable.
1.04	Control equipment is relatively minimal and has been fitted to ply board within the tower where it is connected to new power.
1.05	All reported to be working correctly.
1.06	See further images overleaf.

1.07



Power and control box with RCD.



Equipment protected with polythene. Ply and protection will need to be checked regularly for decay.