

Energy Efficiency and Zero Carbon Advice



The Emmanuel Church Centre **2buy2 Church of England Audits**

Author	Reviewer	Date	Version
Matt Fulford	David Legge	30 th November 2022	1.0



Contents

1. Executive Summary	3
2. The Route to Net Zero Carbon	4
3. Introduction.....	5
4. Energy Procurement Review	6
5. Energy Usage Details	7
5.1 Energy Profiling	7
5.2 Energy Benchmarking	Error! Bookmark not defined.
6. Efficient / Low Carbon Heating Strategy	8
6.1 Air to Air Source Heat Pumps	9
6.2 Install Electric Panel Heaters	11
7. Energy Saving Recommendations.....	12
7.1 New LED Lighting	12
7.2 Lighting Controls (Internal)	12
8. Other Recommendations.....	15
8.1 Electric Vehicle Charging Points	15
9. Renewable Energy Potential.....	15
10. Funding Sources	16
11. Faculty Requirements.....	16
12. Offsetting.....	17
Appendix 1 – Schedule of Lighting to be Replaced or Upgraded.....	18



1. Executive Summary

An energy survey of The Emmanuel Church Centre was undertaken by ESOS Energy to provide advice to the church on how it can be more energy efficient and provide a sustainable and comfortable environment to support its continued use. This audit has been provided in conjunction with 2buy2, the Church of England's Parish Buying scheme provider and is subsidised from Total Gas & Power, the Parish Buying schemes principal energy suppliers.

The Emmanuel Church Centre is modern, unlisted church building which comprises of a community hall (built in the 1970's) and a church extension comprising of a worship space, offices and meeting rooms to the rear built in the 1990's. There is only electricity supplied to the site which used electric night storage heaters supplemented by direct electrical heating units throughout. The building is used frequently throughout the week for community lettings as well as church activities.

The church has a number of ways in which it can be more energy efficient. Our key recommendations have been summarised in the table below and are described in more detail later in this report. It is recommended that this table and the route to net zero carbon are used as the action plan for the church in implementing these recommendations over the coming years.

Energy saving recommendation	Estimated Annual Energy Saving (kWh)	Estimated Annual Cost Saving (£)	Estimated capital cost (£)	Payback (years)	Permission needed	CO2 saving (tonnes of CO2e/year)
Change existing lighting for low energy lamps/fittings	4,733	£1,420	£7,291	5.14	Consult DAC	1.00
Install PIR motion sensors on selected lighting circuits	129	£39	£552	14.29	List B	0.03
Replace heating system for Air to Air Source Heat Pumps in lieu of night storage heaters	13,716	£4,115	£22,179	5.39	Faculty	2.90
Install new suspended ceiling grid and insulate above to older hall area.	2,141	£642	£4,584	7.14	Faculty	0.45
Inject cavity wall insulation into walls of older hall area.	1,713	£514	£2,250	4.38	Faculty	0.36
Consider installing Electric Vehicle Charging Points	0	N/A	£2,500	0.00	List B	-
Install Battery Storage to PV system	0	£-	£10,000	-	Faculty	-
Install a Solar PV array to roof of building	8,791	£2,637	£14,029	5.32	Faculty	1.86



The church should check any faculty requirements with the DAC Secretary at the Diocese before commencing any works.

Based on current market prices of 30p/kWh and 10p/kWh for electricity and mains gas respectively.


If all measures were implemented this would save the church £9,367 per year and reduce its carbon footprint by 6.59 tonnes (99%).

2. The Route to Net Zero Carbon

Our government has committed to move towards Net Zero Carbon – the point at which we have reduced emissions as much as we can and then balanced any residual emissions through removal of carbon from the atmosphere. They have done this as part of a worldwide agreement which aims to limit global warming to well under 2 degrees Celsius, with an aim of keeping it below 1.5 degrees Celsius. This will help protect all of us from the impacts of climate change.

In February 2020, the Church of England's General Synod set its own Net Zero Carbon target. The first stage of this target covers energy used by churches, cathedrals, schools, vicarages, other church buildings, as well as emissions caused by reimbursed transport. The target date is 2030.

This church has a clear route to become net zero by 2030 by undertaking the following step





3. Introduction

This report is provided to the PCC of The Emmanuel Church Centre to give them advice and guidance as to how the church can be improved to be more energy efficient. In doing so the church will also become more cost effective to run and seek to improve the levels of comfort. Where future church development and reordering plans are known, the recommendations in this report have been aligned with them.

An energy survey of The Emmanuel Church Centre, Longsight Rd, Ramsbottom, Greenmount, Bury BL8 4DB, was completed on the 30th of November 2022 by Matt Fulford. Matt is a highly experienced energy auditor with over 15 years' experience in sustainability and energy matters in the built environment. He is a chartered surveyor with RICS and a CIBSE Low Carbon Energy Assessor. He is a Member of the DAC in the Diocese of Gloucester and advises hundreds of churches on energy matters.

The Emmanuel Church Centre	
Church Code	624215
Gross Internal Floor Area	390m ²
Listed Status	Unlisted

The church typically used for 25 hours per week for the following activities

Type of Use	Hours Per Week (Typical)
Services	10 hours per week
Community Use	15 hour per week





4. Energy Procurement Review

Energy bills for electricity have been supplied by The Emmanuel Church Centre and have been reviewed against the current market rates for energy.

The current electricity rates are:

Day Rate	21.11p/kWh
Night Rate	15.07p/kWh
Standing Charge	£9.25/month

A review has also been carried out of the taxation and other levies which are being applied to the bills. These are:

VAT	5%	The correct VAT rate is being applied.
CCL	Not charged	The correct CCL rate is being applied.

The above review confirmed that the correct taxation and levy rates are being charged.



5. Energy Usage Details

The Emmanuel Church Centre uses approx. 31,500 kWh/year of electricity, costing in the region of £9,400 per year based on current market costs. The church is currently purchasing energy below these rates due to long term energy contracts. The total carbon emissions associated with this energy use are 6.64 CO₂e tonnes/year.

This data has been taken from the annual energy invoices provided by the suppliers of the site. The Emmanuel Church Centre has two main electricity meters, serial number E10BG02790 and E10BG38399.


Utility	Meter Serial	Type	Pulsed output	Location
Electricity	E10BG02790	3 phase 100A	Yes	Elec cupboard off WC
Electric Heaters	E10BG38399	1 phase 100A	Yes	Elec cupboard off WC

All the meters are AMR connected and as such energy profile for the entire energy usage should be possible. Half hour meter data has been provided for the purpose of this report and this has been used to verify the data.

5.1 Energy Profiling

The main energy consuming plant can be summarised as follows:

Service	Estimated Proportion of Usage
Lighting	19.6%
Heating	68.0
Other Small Power	12.4%



As can be seen from this data, the heating makes up by far the largest proportion of the energy usage on site.



6. Efficient / Low Carbon Heating Strategy

The energy used for heating a church typically makes up around 80% to 90% of the overall energy consumption. Putting in place a heating strategy that is energy efficient and low carbon is, therefore, of the highest priority

The Church of England is in the process of reviewing its heating guidelines. The process has already established some principles for heating that can help churches as they seek an acceptable combination of comfort, conservation, affordability, and environmental care. The principles can be found at <https://www.churchofengland.org/sites/default/files/2020-04/CBC%20Heating%20guidance%20principles%20FINAL%20issued.pdf>

As the principles make clear, every church's strategy will be unique to it, informed by many factors, including the nature of its usage, the system it's starting from, the conservation needs of the building, and the resources available. The strategies in this audit are designed specifically for your church.

Our recommendations on heating generally fall within three major areas. Firstly, for all churches we make recommendations that will help to reduce energy wastage and, as a starting point, to optimise the system that you already have

Secondly, we recommend options for many churches that focus on heating people rather than the full volume of the church. Some of the changes that can help with this will be 'soft' changes – others will relate to the heating system itself.

Finally, we make recommendations about moving away from fossil fuels. Moves away from fossil fuels are key to cutting emissions. For most churches, this will involve moving from gas, oil or LPG to electricity. Electricity currently creates carbon emissions around the same level as mains gas, but the carbon emissions associated with it are reducing rapidly as the UK builds more renewable energy and decommissions its remaining oil and coal fired power stations. Mains gas does have some potential to reduce its carbon content through the use of bio gas and hydrogen but these are less developed solutions and will be unable to deliver 'zero carbon mains gas'. Some local areas may also be considering the option of district heating networks.

While moving away from fossil fuels may not always be possible, as the principles state, "churches should be expected to have at least carefully considered the option of moving away from fossil-fuel based heating (gas and oil boilers) towards electric-based heating." And if such options are not viable now, the churches "can try to be ready for a future retro-fit when technology and the grid has progressed."

The current heating is electric night storage heaters. These are charged up every night and therefore emit their heat into the building every day regardless of when it is being used. They are also difficult to control and therefore supplemental heating is used by way of electric wall mounted fan or panel heaters as well as plug in fan heaters to warm the building further for specific events. Given the usage profile of the building it would be preferable to have an efficient electric heating system that can quickly warm the space when it is being used and then be off as all other times. This can be best achieved with an air to air heat pump system to the main hall spaces and the use of electric panel heaters to the smaller rooms which are used less frequently. This should be coupled with fabric insulation (replacement of 2 old doors, insulate roof in old



hall area and cavity wall insulation in old hall area) as well as PV panels to the roof to generate some of the electrical needs.

6.1 Air to Air Source Heat Pumps

Air-to-Air Source Heat Pumps (AASHP) work by having an external unit which sucks air in and extracts the heat from it. The pumps concentrate this heat and put it into a refrigeration gas (in the same way as a fridge or freezer works). This refrigeration gas is then piped inside the building in a small pipe where it is then allowed to expand in an internal unit with a fan. This heat is then blown out into the space. This system is identical to an air conditioning system, but it works in reverse to heat the space. As warm air is blown into the space this type of system can heat spaces from cold relatively quickly. Air-to-Air Source Heat Pumps provide around 4.5 units of heat for every 1 unit of electricity used in the heat pump; they therefore have a Coefficient of Performance (CoP) of 4.5.

The Centre for Sustainable Energy model¹ can be used to estimate heat load for the building.

Heat Load (kW) = Volume V (m³) x Insulation Factor

Insulation Factors

Condition	Factor kW/m ³
Poorly insulated with open or broken windows, draughty doors (add 5%)	0.034
Poorly insulated (assume no interventions)	0.033
Some insulating features	Estimate value
Well insulated	0.022
Insulated to 2010 regulations	0.013

Area	Volume m ³	Insulation Factor kW/m ³	Heat Required (Space heating) kW
Church	936	0.022	20.59

Therefore, a heat pump of 20.59 kW would be required.

AASHPs require the installation of external units which look like air conditioning modules in well ventilated external locations. These external units will need an electricity supply and pipework running from them to the heating system. They will also need a drain nearby as the back of the units can build up moisture, which condenses and sometimes freezes on the coils. The larger units do create some low-level noise and therefore the location and baffling of the units may need to be considered carefully.

¹ www.cse.org.uk/local-energy/download/estimating-the-heat-demand-of-a-hypothetical-community-building-79



Examples of external units for ASHP comprising of three smaller 3kW units and two larger 10kW units.

Internal units come in a variety of styles. The most appropriate internal units for most churches are floor mounted units which look very similar to a fan convector heater.

FUA-A - Under ceiling cassette air conditioning unit



Unique under ceiling cassettes for high rooms with solid ceilings or false ceilings with a shallow void. Suitable for all types of commercial applications.

The FUA-A range provides comfortable heating and cooling even for rooms with high ceilings and has individual louvre control flexibility to suit every room layout.

FTXM-R - Wall mount air conditioning unit



Attractive, wall mounted design with perfect indoor air quality. 2 area motion detection sensor: air flow is sent to a zone other than where the person is located at that moment; if no people are detected, the unit will automatically switch over to the energy-efficient setting.



FVXM - Floor Mount Air Conditioning Unit



Designed to fit rooms of any size and shape, it blends well with the interior due to the new design which incorporates more flowing lines and softer edges. These units are ideal when it is not possible to fit a high level wall mount unit for aesthetic or practical reasons.

They are suitable for a wide range of applications including domestic, small to medium offices and commercial uses.

All these units do have a fan element within them and therefore a small amount of fan noise is emitted. This tends to be less than a fan convector heater on a boiler-based system and similar to the noise from a fridge or freezer. Air conditioning units are commonplace in hotel rooms, indicating that the noise is low enough even to be suitable for sleeping environments.

A case study of a church which has installed such a solution is available at [5. Air-source heat pumps at Hethel Church - All Saints Church, Hethel - A Church Near You](#)

6.2 Install Electric Panel Heaters

It is recommended that the PCC consider installing electrical panel heaters in the areas specified in the table below on a time delay switch and remove the existing radiators.

Suitable electric panel heaters would be far infrared panels such as <https://www.warm4less.com/product/63/1200-watt-platinum-white->. These can be purchased widely and fitted by any competent electrician. It is recommended that they are fitted with a time delay switch such as <https://www.danlers.co.uk/time-lag-switches/77-products/time-lag-switches/multi-selectable-time-lag-switch/159-tlsw-ms> so they cannot be left on accidentally after use.

These heaters have a strong radiative effect (where heat is reflected to people from the surface) as well as a light convective effect (where air is warmed and moves around to heat the general space). For this reason, these heaters tend to provide a relatively instant sense of heat and comfort within the space and only need to be on for short periods of time. This reduces the amount of preheating required before each use of the building and can make electric heating cost competitive with gas. It also means that the building can rapidly and economically be brought into used for short or unplanned meetings if needed.

Area	Type/ Size	Length (mm)	Watts	Area Heated	Number required
Meeting Room	Electric Far IR Wall Panel 700W	1200	700	11-18 m2	1
Copier Room	Electric Far IR Wall Panel 580W	1000	580	7-12 m2	1
Vestry	Electric Far IR Wall Panel 580W	1000	580	7-12 m2	1



7. Energy Saving Recommendations

In addition to having a revised heating strategy there are also a number of other measures that can be taken to reduce the amount of energy used within the church.

7.1 New LED Lighting

The lighting makes up a relatively large overall energy proportion of the electricity used within the church. There are very few areas of the building which have had efficient LED lights installed, such as in the WC. Therefore, there still remains a large number of inefficient fluorescent fittings throughout the church, in areas such as the kitchen, corridor, vestry, and meeting room.

It is recommended that the fittings scheduled in Appendix 1 are all changed for LED. There are a vast number of specifications of LED lights on the market, but it is recommended that any LED light should come with branded chips and drivers and offer a 5 year warranty. An example of such a range of fittings is available from <http://www.qvisled.com/>



If all the lights were changed on a simple “like for like” the total capital cost (supplied and fitted) would be £7,300. The annual cost saving would be £2000 resulting in a payback of around 3.5 years. This estimate includes for the supply of the lights, the labour to install them and the access required. It does not include for any upgrade to the wiring or a new lighting design both of which the church may wish to consider. Guidance on lighting, produced by Historic England for churches, can be found at <https://historicengland.org.uk/advice/caring-for-heritage/places-of-worship/making-changes-to-your-place-of-worship/advice-by-topic/lighting/>

7.2 Lighting Controls (Internal)

There are several lights which currently remain on all the time in areas such as the corridor, storage room, vestry, WC, and the like. Some of these areas are only used occasionally and for a short amount of time so that, in actuality, the light does not need to remain on constantly. There are also spaces which benefit from a good amount of natural daylight coming in through the windows, such that artificial lighting is not required for much use during the year.

It is recommended that a motion sensor is installed on these specific lighting circuits so that the lights come on only when movement is detected in the space and turn off approximately two to five minutes after the last movement has been detected (note that the duration of the time lag after which the light goes off needs to be considered alongside the type of light that is fitted. LED lights are much more suited to being switched off after only a short duration than some



fluorescent lights). These movement sensors, commonly called PIRs, also have light sensors integrated into them so they can be used to make sure that the light does not come on if there is already sufficient daylight in the space.


Your existing electrician or any NICEIC registered electrical contractor can install PIR sensors onto existing lighting circuits. This can be carried out without significant disruption to the use of the space.

7.3 Suspended Ceiling and Insulation

There are exposed ceilings to the hall and corridor areas. These have no internal insulation and also do not give the appearance of a modern space. It is recommended that a suspended ceiling is introduced in these areas and then insulation can be added above the new suspended ceiling grid. LED panels could also be fixed within the ceiling grid and an air to air source heat pump units could also be fixed within the grid with the pipework etc., hidden above.

The ceiling of a room is the largest contributing area to heat loss from a building as heat rises. The insulation of such spaces can therefore have a dramatic impact on both the efficiency of the heating system and the temperature of the space below. Insulation measures such as this also need to be combined with control measures such as TRV's or room sensors to ensure that the space does not overheat because of the additional insulation. The insulation is usually fitted in the form of bags or pads sized to the same dimensions of the ceiling tile and therefore it maintains access into the ceiling through the easy removal of ceiling tiles as required.

A free survey and quotation for the supply and installation of insulation above suspended ceiling grids can be arranged through ESOS Energy Ltd (contact Adrian Newton 0117 9309689, adrian@esos-energy.com).






7.4 Cavity Wall Insulation

The older areas of the church (hall) is constructed with a cavity wall method, and the inspection of the wall showed no signs that insulation has been added. Prior to the early 1990's, building regulations did not require walls to be fully insulated and therefore it is likely that there is no insulation present. It could, however, be added through injection into the cavity walls.

It is recommended that cavity wall insulation is considered and added to the walls where appropriate. A survey to check the width of the cavity, exposure of the wall and condition of the cavity should be carried out by a CIGA-approved installer who will then be able to provide you with a quotation to undertake the works. Installing cavity wall insulation will help to reduce heat loss and improve the comfort of the space, but needs to be considered alongside other control measures such as TRV's or room sensors to ensure that the space does not overheat because of the additional insulation.

A free survey and quotation for the supply and installation of insulation to the loft spaces can be arranged through ESOS Energy Ltd (contact Adrian Newton 0117 9309689, adrian@esos-energy.com).



Note greater heat loss from older style walls to right of photo than the newer walls to the left.



8. Other Recommendations

8.1 Electric Vehicle Charging Points



The church has a car park on site. In order to make a visible statement on the church's mission of stewardship and to facilitate more sustainable transport choices by those visiting the church and/or using the hall, the church may wish to consider installing an electric vehicle charging point, probably on the side of the church hall to allow visitors to charge their electric cars.

Installing a unit such as a Rolec Securi-Charge <http://www.rolecserv.com/ev-charging/news/view/Robust-EV-Charging-With-Rolecs-SecuriCharge-EV-Wall-Unit-Coin-Token-PAYG> would allow the organisation control over who is allowed to use the unit with a key operated system. Or given the type of use of the building and control over the usage of the car park as a whole a simple 32 amp type 2 wall pod type charger may be most suitable and these are widely available through many suppliers such as <http://www.rolecserv.com/ev-charging/product/EV-Charging-Points-For-The-Home>.

9. Renewable Energy Potential

The potential for the generation of renewable energy on site has been reviewed and the viability noted.


Renewable Energy Type	Viable
Solar PV	Yes
Battery Storage	Yes

Now that the Feed in Tariff scheme has come to an end the installation of solar PV panels in situations where there is not almost full usage of the electricity generated on site is not really viable.

There is potential for a PV array on the south east facing roof. The current arrangements around solar panels mean that to be financially viable the building on which they are mounted needs to consume the vast majority of the energy that they produce. As the hall has regular daily use a PV system would be viable as its energy would be used for lighting, heating and appliances when the building is being used during daylight hours.



Battery Storage is not strictly a renewable energy solution, but battery storage does however provide a means of storing energy generated from solar PV on site to be able to be used at peak times or later into the day when the PV is no longer generating. It therefore extends the usefulness of the existing PV system particularly in this sort of church and hall.



10. Funding Sources

There are a variety of charitable grants for churches undertaking works and a comprehensive list of available grants is available on this Parish Resources page:

<https://www.pariahresources.org.uk/resources-for-treasurers/funding/>

11. Faculty Requirements

It must be noted that all works intended to be undertaken should be discussed with the DAC at the Diocese.

Throughout this report we have indicated our view on what category of permission may be needed to undertake the work. This is for guidance only and must be checked prior to proceeding as views of different DACs can differ.

Under the new faculty rules;

List A is for more minor work which can be undertaken without the need for consultation and would include changing of light bulbs within existing fittings, repair and maintenance works to heating and electrical systems and repairs to the building which do not affect the historic fabric.



List B is for works which can be undertaken without a faculty but must be consulted on with permission sought from the Archdeacon through the DAC. This includes works of adaptation (but not substantial addition or replacement) of heating and electrical systems and also the replacement of existing boilers so long as the same pipe work, fuel source and flues are used. It can also be used to replace heating controls.

All other works will be subject to a full faculty.

Works which affect the external appearance of the church will also require planning permission (but not listed building consent) from the local authority and this will be required for items such as PV installations.

12. Offsetting

As you take action to reduce your emissions, you may also wish to offset those that you cannot yet reduce. If you would like to engage in offsetting, it is important to use a reputable scheme. The Church of England recommends Climate Stewards, which has a simple calculator that can help you to work out how much you would need to offset. <https://www.climatestewards.org/>

Climate Stewards encourages people to 'reduce what you can and offset the rest' as part of your journey to Net Zero carbon emissions. They provide training and resources to help you understand climate change and its impacts, and to calculate the carbon footprint from your activities including travel, energy, expenditure, and food. Their online carbon calculators for individuals and smaller organisations are free to use, and they provide bespoke carbon footprint audits for larger organisations.

Having reduced as much of your organisation's carbon footprint as you can, there will always be unavoidable emissions from your work and travel. Carbon offsetting allows you to compensate for the negative impact of your carbon emissions by funding projects which take an equivalent amount of CO₂ out of the atmosphere. These either involve locking up ('sequestering') CO₂ as trees grow or reducing emissions by using low-carbon technology such as fuel-efficient cookstoves or water filters.

Climate Stewards has a close relationship with all their project partners in Ghana, Uganda, Kenya, Tanzania, Nepal, and Peru. They work closely with them to design, develop, implement and monitor projects which will not only mitigate carbon, but also bring tangible benefits to the local community - including improved health, savings in time and money previously spent on buying or collecting fuel, and improvements in local biodiversity. Each project is assessed using their Seal of Approval protocol which enables us to assess and monitor carbon mitigation and ensure robust, sustainable, and transparent partnerships.



Appendix 1 – Schedule of Lighting to be Replaced or Upgraded

Room/Location	Number of Fittings	Recommended Upgrade	Annual Saving (£)	Total Cost (£)	Payback
Kitchen	2	5ft Single Vapour LED	£59	£162	2.76
Corridor	2	2D LED 11W	£48	£134	2.81
Front corridor	4	5ft Single LED	£147	£351	2.39
Canon Lewis Hall	12	5ft Single LED	£566	£1,054	1.86
Storage rooms	4	LED GLS	£50	£48	0.96
Church	17	5ft Single Proteus LED	£632	£2,164	3.42
Church	19	GU10 LED	£644	£1,189	1.85
Church entrance	3	600 x 600 25W Panel	£323	£225	0.69
Vestry	3	600 x 600 25W Panel	£323	£225	0.69
Store	1	600 x 600 25W Panel	£46	£75	1.64
Copier room	3	600 x 600 25W Panel	£323	£225	0.69
Small meeting room	6	600 x 600 25W Panel	£273	£449	1.64