

From: James Takle <james@refelectrics.co.uk>
Sent: Friday, May 19, 2023 8:01 PM
To: Michael Vaughan <Michael@b2architects.com>
Subject: RE: 0566 TRULL All Saints - Electrical Inspection

Hi Michael,

Please find attached certificate following completion.

The certificate is Unsatisfactory overall.

The installation in certain areas is showing signs of breaking down and with the overall age, it will only get worse as time goes on.

You are looking a part rewire in some areas and then it's a client decision to decide whether it makes sense to rewire it all.

Perhaps incorporate it with the lighting scheme you mentioned as there is no point rewiring to old positions if the church would benefit from new positions with the new scheme.

Yes, you could complete some of the items and therefore get a Satisfactory certificate for insurance, but its not going to mask the age which must be somewhere in the region of 70 plus years which is past its life expectancy.

I'm happy to meet onsite should you wish to discuss further and produce a scheme as I assume you have the drawings in DWG format.

Kind Regards

James Takle



Tel: 01823 282339
Mobile: 07921 157 890
Fax: 01823 321390
Email: james@refelectrics.co.uk

22 Acorn Centre, Livingstone Way, Taunton, Somerset, TA2 6BD, Registered in England No: 1264319

NOTICE: This message and any attachments are private and confidential. If you have received this message in error, please notify us and remove it from your system. Any unauthorised use, disclosure or copying of this email , or attachments it contains is prohibited.

WARNING: Computer viruses can be transmitted via email. The recipient should check this email and any attachments for the presence of viruses. REF Electrics (Taunton) Ltd accepts no liability for any loss or damage caused by any virus transmitted by this email.