

## **CERTIFICATE OF PRACTICAL COMPLETION**

### **St. John the Baptist Church in the parish of Harringworth**

Relating to: Work to lift and relay a blocked surface water pipe under the graveyard being approved by a faculty application number 2024 – 101 720.

Noted the work was managed without any changes to existing ground level drainage gulleys and by rodding and jetting the existing drains rather than needing to lift and relay.

Tree roots from Holly Tree numbered 9997 had grown into the pipe at the downstream end but this was cleared.

The manholes and soakaways on the adjacent (not church) property were cleared/rebuilt and extended as necessary under my inspection.

Issued by: Alan Wordie, Chartered Surveyor, of Endurance Property, Land and Property Consultancy

The Old Vicarage, Harringworth, Northamptonshire NN17 3AF

Issued to: Stuart Naylor of SJN Builders Limited  
4 Top Lane, Bisbrooke LE15 9ER

Dated: 7<sup>th</sup> March 2025

Signed: *Alan J K Wordie*