07288

EIC18_3

ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with BS 7671: 2018 (as amended) - Requirements for Electrical Installations

Original (to the

DETAILS OF THE CONTRACTOR, CLIENT AND INSTALLATION DETAILS OF THE CONTRACTOR Registration No. 607775 Registration No. 6	DETAILS OF THE INST OQ 2507 S.T. M.Q.K Lead, An addition: () An alteration: () D.B. Q.A.d. M.E.d. T. C.i. C.j. E.S. Where necessary, continue or alteration see Regulation 644.1.2) Where necessary, continue or alteration see Regulation 644.1.2)	DETAILS OF THE INSTALLATION Occupier: Same as S. Unique Property Reference Number (UPRN):
HE ELECTRICAL WORK COVERED BY THIS INST ○ 8 , 2 0 2 5 The Installation is an covered by this certificate: New いうらもはしならられ	wearing	
PART 3 : COMMENTS ON THE EXISTING INSTALLATION (in the case of an addition or alteration see Regulation 644.1.2)		
Phase rotation observed at		e necessary, continue on a separate numbered page: Page No(s) ()
PART 4A: DECLARATION FOR THE ELECTRICAL INSTALLATION WORK (use where the design, construction, inspection & testing have been the responsibility of one person) DESIGN, CONSTRUCTION, INSPECTION & TESTING (the extent of liability of the signatory is limited to the work detailed in PART 2) I, being the person responsible for the design, construction, inspection and testing of the electrical installation, particulars of which are described in PART 2, having exercised reasonable skill and care when carrying out the design, hereby CERTIFY that the design, inspection and testing for which I have been responsible is to the best of my knowledge and belief in accordance with 8S 7671: 2018 amended to	the design, construction, inspection & PART 2) ibed in PART 2, having exercised reasonable skill and to 2004. (date) except for the departures, if	onstruction, inspection & testing have been the responsibility of one person) aving exercised reasonable skill and care when carrying out the design, hereby CERTIFY that the design, construction, (date) except for the departures, if any (Regulations 120.3, 133.1.3 and 133.5), detailed as follows:
* Permitted exception applied (411.3.3): Yes/NA () Risk assessment attached: () Page No(s) () I, being the designer of the electrical installation, also RECOMMEND that this installation is further inspected and tested by: 29.08.2030 (date) The proposed date for the next inspection should take into consideration any legislative or licensing requirements and the frequency and quality of maintenance that the installation can reasonab Name (capitals): MATTNEW DOWNS Name (capitals): MATTNEW DOWNS Name (capitals): MECCIESOII TOOD Sheffield	asonably be expected to receiv	where required, continued on attached separate page(s) () We expected to receive during its intended life. The period should be agreed between relevant parties Registration No*: 607775
Date: 2º	Allthum OTS 115	_{101 No.} 03333398929

This certificate is based on the model forms shown in Appendix 6 of *BS 7671: 2018* (as amended) @ Copyright Certsure LLP (August 2024)

Enter a (\checkmark) or value in the respective fields, as appropriate. Where an item is not applicable insert N/A

Please see the 'Notes for Recipients'

Page 1 of

Vi



This cerestate is not valid if the serial number has been defaced or altered

07288

EIC18.3

ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with BS 7671: 2018 (as amended) - Requirements for Electrical Installations

PART 4B: DECLARATION FOR THE ELECTRICAL INSTALLATION WORK (to be completed where different parties are responsible for the design, construction, inspection & testing)
DESIGN (The extent of liability of the signatories is limited to the work detailed in PART 2)
I/We being the person(s) responsible for the design of the electrical installation, particulars of which are described in PART 2, having exercised reasonable skill and care when carrying out the design, hereby CERTIFY that the design work for which I/we have been responsible is to the best of my/our knowledge and belief in accordance with 8S 7671: 2018 amended to(date) except for the departures, if any, detailed on attached page(s) (
Permitted exception applied (411.3.3): Yes/NA Risk assessment attached: () Page No(s) ()
DESIGNER 1 Name (capitals).
DESIGNER 2 (where there is divided responsibility for design) Name (capitals): Signature: Signature:
("Where applicable) I (we, being the designer(s) of the electrical installation, also RECOMMEND that this installation is further inspected and tested by:(date) The proposed date for the next inspection should take into consideration any legislative or licensing requirements and the frequency and quality of maintenance that the installation can reasonably be expected to receive during its intended life. The period should be agreed between relevant parties.
Organisation (Designer 1):
Address: Address:
Postcode:
CONSTRUCTION (The extent of liability of the signatory is limited to the work detailed in PART 2) Libering the person responsible for the construction of the electrical installation, particulars of which are described in PART 2, having exercised reasonable skill and care when carrying out the construction, hereby CERTIFY that the said work for which I have been responsible is, to the best of my knowledge and belief, in accordance with 85 7671: 2018 amended to(date) except for the departures, if any, detailed on attached page(s) () (Regulations 120.3 and 133.5).
Name (capitals): Organisation: Organisation:
Address
Signature: Postcode: Postcode: Tel No:
NSPECTION & TESTING (The extent of liability of the signatory is limited to the work detailed in PART 2) I, being the person responsible for the inspection and testing of the electrical installation, particulars of which are described in PART 2, having exercised reasonable skill and care when carrying out the inspection and testing, hereby CERTIFY that the said work for which I have been responsible is, to the best of my knowledge and belief, in accordance with BS 7671: 2018 amended to
Name (capitals):
Address:
REVIEWED BY QUALIFIED SUPERVISOR (for the Contractor detailed in PART 1)
Cionatiro

Where the electrical work to which this certificate relates includes the installation of a fire alarm system and/or an emergency lighting system (or a part of such systems), this electrical safety certificate should be accompanied by the particular certificate(s) for the system(s).



Name (capitals):



number has been defaced or altered This certificate is not valid if the serial

07288

EIC18_3

ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with BS 7671: 2018 (as amended) - Requirements for Electrical Installations

n sheets	Continuation sheets Page No(s):	Schedules relating to Prosumer's installations (Indicated in Item 14 of PART 7) Page No(s): () Page No(s):	Special Installations or locations (Indicated in Item 13 of PART 7) Page No(s): (Additional pages, including data sheets for additional sources Page No(s): ()	Schedule of Circuit Details and Schedule of Test Results for the installation (PARTS 9A & 9B) to Page No(s): (
		Regulation 653.2))	ed are an essential part of this report (see	IONAL PAGES (the pages identifi	PART 8: SCHEDULES AND ADDITIONAL PAGES (the pages identified are an essential part of this report (see Regulation 653.2))
DOWNS. 29.08,25		() 14. Prosumer's low voltage installation(s) () Schedule of Items Inspected by () Name (capitals). MATTHEW () Signature: The Company of the Com	Circuits (distribution and final) Isolation and switching Current-using equipment (permanently connected) Identification and notices	11 10 8 8	3. Protective measure: Automatic disconnection of supply (ADS) 4. Basic protection 5. Protective measures other than ADS
Outco (Z.L.	or shower locations		Additional protection Distribution equipment		
			applicable)	OF ITEMS INSPECTED (enter ✓or N/A, as applicable)	PART 7: SCHEDULE OF ITEMS IN
Rating / setting of device: (125) A Voltage rating: (1409) V RCD Type: () Measured operating time: () ms)) Meas	No. of poles: () Where an RCD is RCD rated residue	Gas installation pipes: Structural steel: Oil installation pipes: Lightning protection: Other (state):	(material COPPES csa (1.9) mm² Connection/continuity verified: () Main protective bonding conductors: (material COPPES csa (1.6.) mm² Connection/continuity verified: ()	
			Main protective bonding connections Water installation pipes:	ALLATION REFERRED TO IN THE Main protective conductors Earthing conductor:	PART 6: PARTICULARS OF INSTALLATION REFERRED TO IN THIS CERTIFICATE Maximum demand (load): (「! O.つ) かん
(5.0)# (4:9)# (0-19)	200	Nominal frequency, f [1]: (. \times) Other: (Rated current: (\lambda.\text{QSO}\)A Other sources	Supply protective device BS EN: (
(400) V (1) By enquiry		2-phase, 3-wire: () Nature of supply parameters Nominal voltage between lines, U [1]; Nominal line voltage to Earth, U _Q [1];	Number and type of live conductors AC 1-phase, 2-wire: () 2-phase, 3-phase, 3-wire: () 3-phase,	TN-C-S: () Number and t	System type and earthing arrangements TN-C: () TI: () II: ()
			SEMENTS	ICS AND EARTHING ARRANG	PART 5 : SUPPLY CHARACTERISTICS AND EARTHING ARRANGEMENTS

@ Copyright Certsure LLP (August 2024) This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018 (as amended)

*Where the installation is supplied by more than one source, the higher or highest values of prospective fault current, lpf, and external earth fault loop impedance, Ze, must be recorded.

Where an item is not applicable insert N/A Enter a (\checkmark) or value in the respective fields, as appropriate.

Page 3 of

ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with BS 7671: 2018 (as amended) - Requirements for Electrical Installations

* RCI	. M. F	1 =	: <u>Ç</u> :			FL	27	11	\$13	312	31)	223	212	77	5	112	1		Circuit numbe	r	P
* RCD effectiveness is verified using an alternating current test at rated residual operating current (b_{lpha})	Insulation Continuity: Insulation I	TESTED BY	Circuits/equipment vulnerable to damage when testing (where applicable):			51.0 [7]	110027	_		,	_		, -					راne)	(a R		H 9B
ness is ve	H380445	Nam	ment vulne			0.15	0.1											(Neutral)	Ring final circuits only (measured end to end)		SCHE
rified usin	4S	Name (capitals): TATTHEW DOWNS	лиlnerable to damage when testing (where applicable):			-	0.21											(cpc)	Its only to end)	Continuity (a)	BULE
g an alter	SEKIAL	7	mage wher			0.260.08	11 0.04					0.11	0.47	0,15	51.0	50°1			ହ	ty (n)	OF TE
nating cur	Continuity:	TTL	testing (w			80	40					(1)	++	15	51	50		(R + R,)	All circuits (complete at least one column)		ST RES
rent test a	ontinuity:	J T W	here applic			0	٩					0	0	a	٩	٥		,7"			SULTS
it rated rea	EACH	000	able):			999	999					999 999		999	999	999		(MD)	Live /	Insula	(MUST
sidual ope	No Inch	E Z				999	999							999	999	999		(MD)	Live / Earth	Insulation resistance	reflect c
rating cur	Insulati	SNT IIOE				500	500					500	500	500	009	500		3	Test voltage DC	nce	ircuits e
ent $(I_{\Delta n})$	Insulation resistance	Position:				<	<					<	5	<	<	<		S	Polarity		ntered ir
	ice:	Position: Electricia /				0.23	0.19					0.26	0.62	0.30	0.80 29	1.20		Đ		оор	nto 'Sche
** Where in		ErîC)				29	29					. 68	28	87	29	29		(ms)	PART 9B:SCHEDULE OF TEST RESULTS (MUST reflect circuits entered into 'Schedule of Circuit Details' in Part 9A) Continuity (I) Insulation resistance Ring final circuits only (measured end to end) All circuits (measured end to end) Complete at least one column) Live Live / Live / Voltage Live / Voltage		
installed. I	Earth	۾ ک				<	\					<u> </u>	<u> </u>	<u> </u>	<u> </u>	<		S	Test button		Circuit E
Note, not a	fault loop i			-														S	AFDD test button	AFDD**	etails' i
all AFDDs have a test fu	Earth fault loop impedance:	Signature:																			in Part 9A)
Inction. Where a circuit contains an AF	Earth electrode resistance:	(Druss																	Comments and additional information, where required		
** Where installed. Note, not all AFDDs have a test function. Where a circuit contains an AFDD this should be stated in the field for that	RCD:	29.08.25																	n, where required		

This certificate is based on the model forms shown in Appendix 6 of BS 7671: 2018 (as amended) @ Copyright Certsure LLP (August 2024) (A) Thermoplastic insulated / sheathed cables

Where an item is not applicable insert N/A Enter a (\checkmark) or value in the respective fields, as appropriate. (B) Thermoplastic cables (C) Thermoplastic cables (D) In metallic conduit (D) In metallic conduit (D) In metallic tunking (E) Thermoplastic cables (F) Thermoplastic / SWA cables (G) Thermosetting / SWA cables (H) Minaral-insulated cables Other (states).

circuit in the 'Comments and additional information, where required' column.

Page 5 of U



07288

EIC18.3

ELECTRICAL INSTALLATION CERTIFICATE

Issued in accordance with BS 7671; 2018 (as amended) – Requirements for Electrical Installations

PART 9A: SCHEDULE OF CIRCUIT DETAILS (GO TO Part 9B 'Schedule of Test Results' to enter test results for the corresponding circuit listed in this part)

DISTRIBU: DB designatic Location of DI Z _{db} : Confirmation SPD Details*		LOC	42 Lov	11 Space	313 Spare	312 Space	321 Space	23 Toilet	12 Toilet	ヹ	0	17 D & O	4 SP		Circuit numbe	r
DISTRIBUTION BOARD (DB) DETAILS (complete in every case) DB designation: $\bigcirc B \ \mathcal{U}$ DB designation: $\bigcirc B \ \mathcal{U}$ Location of DB: $\bigcirc \bigcirc \bigcirc$		-ounge area? - Heaters	ounge area 1 - Heaters	<u> </u>	<i>پر</i> د	(CE	166	heaters	3	heate	ffice heaters	1 heaters	Pare.		Circuit description	
		c)E	CIE					CIE	CIE	310	310	310		(se	Type of wiring e footer to PAR	
**SPD Type. Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking both Type brackets. Where T3 devices are installed on a circuit to protect sensitive equipment, enter details in 'Comments' (PART 9B), (See Section 534 for further details). Note that not all SPDs have visible functionality indication.		G	3					B	B	B	B	B		R	eference Meth (BS 7671)	od
e, nbined T1 + rstalled, inc kets, devices are devices are Sensitive ec Comments' on 534 for f not all SPD; ty indicatio		W						_	-	1	-	1		Num	ber of points s	erved
**SPD Type. Where combined T1 + T2 or T2 + T3 device is installed, indicate by ticking Type brackets. Where T3 devices are installed on a of to protect sensitive equipment, enter details in 'Comments' (PART 9B), (See Section 534 for further details). Note that not all SPDs have visible functionality indication.		5,62	2225					2.5	2.5	2,5	2.5	2,5		(mm²)	Live	Circuit conductor (number & csa)
T3 king both n a circuit nter nter lis).		S.1.2	7,1.5					<u>ે</u>	てい	1.5	U	1.5		(mm²)	срс	nductor & csa)
TO BE CO Supply to I Overcurre BS (EN): (. Associate BS (EN): (.	*	4.0	4.0					0.4	4.0	0.4	4.0	0.4		(s)	Max. disconr time (BS 7	
TO BE COMPLETED ONLY IF THE DB IS NOT CON Supply to DB is from: DS). Overcurrent protective device for the distribution circuit BS (EN): (6.898), Type: (C) Nom Associated RCD (if any) BS (EN): (61009	61009					6009	61009	61009	61009	61009			BS (EN)	
IF THE D		B						B		2	B	S			Туре	Overcurren
B IS NOT I		32	32 10					6		6	16	16		(A)	Rating	Overcurrent protective device
ONLY IF THE DB IS NOT CONNECTED DIRECTED DIRECTE		ō						0	ō	0	ō	0		(kA)	Short- circuit capacity	rice
ED DIRECTLY tage: (4-00		48.1	1.37					2,73		2.73	2,73	2,73		(n)	Maximum permitted Zs*	
ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION OSCILLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE DB IS NOT CONNECTED DIRECTLY TO THE ORIGIN OF THE INSTALLATION ONLY IF THE ORIGIN OF THE ORIGIN OF THE INSTALLATION ONLY IF THE ORIGIN OF THE		61009	61009	7 .				61009	60009	61009	61009	61009			BS (EN)	
N OF THE		A	Э					Э	A	D	Þ	A			Туре	RCD
THE INSTALLATION A No. of phases: () ms Operating time: () ms		32						16	16	16	16	16		(A)	Rating	
(W) ms		30	30					30	30	30	30	30		(mA)	Operating current,	

Page 4 of

S