

West Harptree - Proposed cabling routes

North Nave and Alter



TH3000 Omit
Replaced by St

South Nave and Alter



TH3000 Omit
Replaced by St



moved away
from organ

DB2 Submain

* black SWA clipped to backside of rafter

* cabling located behind wainsplate out of sight.

South door overdoor heater BN Thermic

South Aisle



DB2 Confirmed location



clipped direct, alternative route above wall plate above and drilled through

- Submain Route
- Power to heaters
- DB2

~~Located in Chancel on reverse~~

* relocated to South Aisle



relocated on to South wall.

