

25/08/2017

GWS/SS/R6028

Electrical Inspection Report.

To Comply with:

BS7671:2011

Regulations for Electrical Installations

IEE Wiring Regulations – 17th Edition

Completion of electrical works to Periodic Test and Inspection report 6028 St Marys Church Stone

Works completed by:

CES Complete Electrical Services

nic EIC
UKAS EN45011.

25/08/2017

GWS/SS/R6028

Contents of Works Completed.

This is a declaration to confirm that the following observations found to report GWS/SS/R6028 dated 11th May 2015 have now been completed. All these items that were noted in the report as dangerous are now deemed safe.

COMPLETED ITEMS- Sept 2015

| <u>Item.</u> | <u>Description.</u> | <u>Code.</u> | |
|---------------------|---|---------------------|-----------|
| 1.1 | To re-wire the organ socket circuit and replace the protective device. | 2 | Completed |
| 1.4 | D.B 1 CCT 5 – To replace the connection box within the tower. | 2 | Completed |
| 1.6 | D.B 1 CCT 5 – To replace the connections with insulated connection crimps | 2 | Completed |
| 2.2 | To replace the external light copex connection with new PVC type. | 2 | Completed |

COMPLETED ITEMS- August 2017 – New Lighting Installation.

| <u>Item.</u> | <u>Description.</u> | <u>Code.</u> | |
|---------------------|--|---------------------|-----------|
| 1.2 | To re-wire D.B 1 CCT 4 East Nave lighting circuit. | 2 | Completed |
| 1.3 | To re-wire D.B 1 CCT 5 Nave, North Aisle & tower lighting circuit. | 2 | Completed |
| 1.7 | To re-wire D.B 1 CCT 6 | 2 | Completed |

INCOMPLETED ITEMS.

| <u>Item.</u> | <u>Description.</u> | <u>Code.</u> | |
|---------------------|--|---------------------|------------|
| 1.5 | To install cable clips to correctly secure the external light cable run. | 3 | Incomplete |
| 1.8 | To replace D.B 1 CCT 2 with an RCBO. | 3 | Incomplete |
| 2.1 | To correctly install the external lighting SWA cable. | 3 | Incomplete |

25/08/2017

GWS/SS/R6028

Works Information.

Engineers. Craig Smith

Date. 13th August 2017

NEXT TEST. May 2020

Signed by Senior Engineer.



Print Name. RYAN SLESSENGER

Date. 25/08/2017

The schedules along with this document should be attached to the electrical report and placed in your Health and Safety file.